

ENCLOSURE TO
SERIAL NO. NLS-85-267
PROPOSED BRUNSWICK-2
TECHNICAL SPECIFICATION PAGE

8507180184 850712
PDR ADOCK 050C0324
P PDR

SUMMARY LIST OF REVISIONS

Page

Description of Change

3/4 6-8

1. Footnote allowing temporary increase in primary containment average air temperature limit added to Section 3.6.1.6.
2. "CONDITIONS" changed to "OPERATIONAL CONDITIONS".

CONTAINMENT SYSTEMSPRIMARY CONTAINMENT AVERAGE AIR TEMPERATURELIMITING CONDITION FOR OPERATION

3.6.1.6 Primary containment average air temperature shall not exceed 135°F.*

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

With the primary containment average air temperature > 135°F*, reduce the average air temperature to within the limit within 8 hours, or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 12 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The primary containment average air temperature shall be the volumetric average of the temperatures at the following locations and shall be determined at least once per 24 hours:

Location

- a. Below 5' elevation,
- b. Between 10' and 23' elevation,
- c. Between 28' and 45' elevation,
- d. Between 70' and 80' elevation, and
- e. Above 90' elevation.

* The primary containment average air temperature limit may be increased to 140°F until August 15, 1985, at which time the limit will be returned to 135°F.