

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-85-63

Date: 09/24/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Portland General Electric Company
Trojan Nuclear Plant
Docket No. 50-344
Portland, OR 97204

Emergency Classification
___ Notification of Unusual Event
___ Alert
___ Site Area Emergency
___ General Emergency
XX Not Applicable

SUBJECT: REACTOR TRIP AND SUBSEQUENT SHUTDOWN FOR GREATER THAN 48 HOURS

The reactor tripped from 100% power at 8:38 am, PDT, on September 24, 1985, because of low-low steam generator level due to the loss of a main feedwater pump. The pump tripped on low suction pressure as a result of flow oscillations in the condensate system which were caused by work in progress on the condensate demineralizer system. The feedwater pump trip caused a turbine runback, however this was not sufficient to maintain steam generator levels which resulted in the reactor trip. All systems functioned normally following the trip.

The reactor will be taken to Mode 5 to repair pressurizer safety valves which were leaking prior to the trip. Due to the safety valve repairs and other miscellaneous maintenance, startup is not expected until October 1, 1985.

This information is current as of 10:00 am, PDT, September 24, 1985.

CONTACT: R. Dodds S. Richards
FTS 463-3720 (503) 556-3751

DISTRIBUTION

H St. 9:31 MNBB 9:14 Phillips 9:13 E/W 9:28 Willste 9:29 Air Rights 9:40 Mail:
Chairman Pallidino EDO NRR IE NMSS ADM:DMB
Comm. Zech PA OIA RES DOT:Trans Only
Comm. Bernthal MPA AEOD
Comm. Roberts ELD
Comm. Asselstine
SECY Regions: RI-9:58 RII-9:59 RIII-9:59 RIV-10:02
ACRS INPO 10:18 NSAC 10:17
CA Licensee: 12:42
PDR (Reactor Licensees) REGION V: FORM 211
Resident Inspector 10:59 (Revised 3/14/83)

8510010190 850924
PDR I&E
PNO-V-85-063 PDR

IE-34
0/1