

GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

July 12, 1985

Mr. John A. Zwolinski, Chief
Operating Reactors Branch No. 5
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555


Dear Mr. Zwolinski:

Subject: GPU Nuclear Corporation (GPUN)
Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Fire Protection

By letter dated April 3, 1985, GPUN submitted the "Oyster Creek Fire Hazards Analysis Report and Section III.G Safe Shutdown Evaluation" Revision No. 3. In discussion with the NRC staff, the GPUN approach to manual actions from the control room prior to evacuation was found unacceptable without backup provisions outside the control room area. Based on these discussions, GPUN has prepared the enclosed revision no. 4 to the submittal which incorporates alternate means, outside the control room, to accomplish vessel isolation, feedwater pump trip, and recirculation pump trip.

If you should have any questions concerning this submittal, please contact Mr. Michael Laggart at (201) 299-2341.

Very truly yours,


P. B. Fiedler
Vice President and Director
Oyster Creek

8507180200 850712
PDR ADDCK 05000219
F PDR

j

cc: Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station Forked River, NJ 08731

A006
1/1