

JUL 15 1985

Docket No. 50-219
License No. DPR-16

GPU Nuclear Corporation
ATTN: Mr. P. B. Fiedler
Vice President and Director
Oyster Creek Nuclear Generating Station
P. O. Box 388
Forked River, New Jersey 08731

Gentlemen:

Subject: Inspection Report No. 50-219/85-15

This refers to the routine resident safety inspection by Messrs. W. Bateman and J. Wechselberger from May 6 - June 2, 1985, at the Oyster Creek Nuclear Generating Station. The inspection consisted of document reviews, interviews, and observations of activities as documented in the enclosed inspection report. The findings were discussed with you and members of your staff at the conclusion of the inspection.

Within the scope of this inspection, no violations were identified.

We acknowledge receipt of your May 10, 1985 response to Violation 85-06-05 involving failure to establish system internal leakage tests as required by paragraph 6.15 of Technical Specifications and your May 10 and 30, 1985 responses to Violation 85-06-01 concerning failure to perform a valve lineup after Core Spray system modification. Your corrective actions will be reviewed during future inspections.

This Inspection Report also summarizes the meeting held in Region I with members of GPUN management to discuss GPUN's plans to address the concerns raised during Inspection 85-14 involving GPUN's responses to NRC Bulletins 79-02 and 79-14.

Your cooperation with us in these matters is appreciated.

Sincerely,

Original Signed Copy

Harry B. Kister, Chief
Projects Branch No. 1
Division of Reactor Projects

Enclosure:
NRC Region I Report 50-219/85-15

OFFICIAL RECORD COPY

IR OYC 85-15 - 0001.0.0
07/02/85

8507180219 850715
PDR ADOCK 05000219
Q PDR

1E01

cc w/encl:

BWR Licensing Manager
Licensing Manager, Oyster Creek
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New Jersey

bcc w/encl:

Region I Docket Room (with concurrences)
Senior Operations Chief (w/o encl)
DRP Section Chief
DRS Director
DRSS Director

RI:DRP
Boteman
7/1/85

RI:DRP
Conner
7/8/85

RI:DRS
Eapen
7/10/85

RI:DRP
Kister
7/12/85

OFFICIAL RECORD COPY

IR OYC 85-15 - 0001.1.0
07/02/85