



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

NSD-NRC-96-4918
DCP/NRC0688
Docket No.: STN-52-003

December 18, 1996

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: T. R. QUAY

SUBJECT: PIPING FUNCTIONAL CAPABILITY

Dear Mr. Quay:

As promised during the meeting with the NRC staff on December 6, 1996 Westinghouse is revising the criteria for piping functional capability to be included in the AP600 SSAR. A draft mark-up of Table 3.9-11 is attached. Also, the following two references will be added to the SSAR.


19. "Functional Capability Criteria for Essential Mark II Piping," General Electric Company, NEDO-21985, 78NED174, E. C. Rodabaugh, September, 1978.
20. "Functional Capability of ASME Class 2/3 Stainless Steel Bends and Elbows," ASME 83-PVP-66, T. H. Liu, E. R. Johnson, K. C Chang.

The seventh paragraph of subsection 3.9.3.1.5 will be revised as follows:

The functional capability requirements for ASME piping systems that must maintain an adequate fluid flow path to mitigate a Level C or Level D plant event are shown in Table 3.9-11. These requirements are based on references 19 and 20.

These changes will be included in Revision 10 of the SSAR.

If you have any changes please contact Donald A. Lindgren at (412) 374-4856 if you have any questions.


Brian A. McIntyre, Manager
Advanced Plant Safety and Licensing

/jml

attachment

cc: D. Jackson, NRC, (attachment)

EO04 1/1 -



Table 3.9-11 (sheet 1 of 3)

**PIPING FUNCTIONAL CAPABILITY - ASME
CLASS 1, 2, AND 3⁽¹⁾**

Wall Thickness:	$D_o/t \leq 50$, where D_o , t are per ASME III
Service Level D Conditions	Equation 9 \leq smaller of $2.0 S_y$ and $3.0 S_m^{(2, 4)}$ Equation 9 \leq smaller of $2.0 S_y$ and $3.0 S_h^{(3, 4)}$
External Pressure:	$P_{\text{external}} \leq P_{\text{internal}}$
TE + SCVE	$C2 * M * D_o / 2I \leq 6.0 S_m^{(2)}$ (NB-3650) Equation 10a (NC3653.2) $\leq 3.0 S_c^{(3)}$
TF + SCVF	$C2 * M * D_o / 2I \leq 6.0 S_m^{(2)}$ (NB-3650) Equation 10a (NC 3653.2) $\leq 3.0 S_c^{(3)}$
DW	$\frac{B2 * M}{Z} \leq 0.25 S_y$

Notes:

1. Applicable to Level C or Level D plant events for which the piping system must maintain an adequate fluid flow path
2. Applicable to ASME Code Class 1 piping for all loading conditions and analysis methods
3. Applicable to ASME Code Class 2 and 3 piping when the following limitations are met:

3.1 Dynamic loads are reversing (slug-flow water hammer loads are non-reversing)

3.2 Dynamic moments are calculated using an elastic response spectrum analysis with 15 % peak broadening and not more than 5 % damping

3.3 Steady-state bending stress does not exceed:

$$\frac{B2 * M}{Z} \leq 0.25 S_y$$

4. ~~Applicable to reversing dynamic loads and to fluid hammer slug-flow loads~~ For ASME Class 2 and 3 piping that does not satisfy the limitations in note 3 above, functional capability is assured when the equations on sheets 2 and 3 are met.



Table 3.9-11 (sheet 2 of 3)

**PIPING FUNCTIONAL CAPABILITY - ASME
CLASS 1, 2, AND 3**

Component	Stress Calculation	Stress Limit
Straight Pipe ⁽⁵⁾	$PD_o/4t + M/Z$	1.5 Sy
Branch ⁽⁶⁾	$3I^{(6)} * PD_o/2t + B2b^{(6)} * Mb/Zb + B2r^{(6)} * Mr/Zr$	2.0 Sy
Stainless Steel Elbow ⁽⁷⁾	$B1^{(7)} * PD_o/2t + B2^{(7)} * M/Z$	1.8 Sy
Non-stainless Steel Elbow ⁽⁸⁾	$B1^{(8)} * PD_o/2t + B2^{(8)} * M/Z$	1.5 Sy
Reducer ⁽⁹⁾	$PD_o/4t + FCI^{(9)} * M/Z$	1.5 Sy
Butt Welding Tee ⁽¹⁰⁾	$B1^{(10)} * PD_o/2t + B2b^{(10)} * Mb/Zb + B2r^{(10)} * Mr/Zr$	2.0 Sy
Fabricated Tee ⁽¹¹⁾	$PD_o/4t + FCI^{(11)} * M/Z$	1.5 Sy

Notes:

5 Includes butt-welded joint, 30 degree tapered transition, fillet-welded joint, socket-welded flange, single-welded slip-on flange, and brazed joint.

6 $B1 = 0.5$, except if either $B2b$ or $B2r$ is $4/3$, then $B1 = 2/3$

$$B2b = 1.5(R_m/T_r)^{2/3}(r_m'/R_m)^{1/2}(T_b'/T_r)(r_m'/r_p), \text{ but not less than } 4/3$$

$$B2r = 0.6(R_m/T_r)^{2/3}(r_m'/R_m), \text{ but not less than } 4/3$$

R_m , T_r , r_m' , T_b' , T_r , and r_p based on ASME III, NB3600

Table 3.9-11 (sheet 3 of 3)

PIPING FUNCTIONAL CAPABILITY - ASME CLASS 1, 2, AND 3

Notes:

- 7 $B1 = -0.1 + 0.4h$, but not less than 0.0 nor greater than 0.5. Also, for $B2 = 1.0$, $B1 = 0.5$

$$B2 = 1.3/h^{2/3} \text{ for } \alpha > 90 \text{ degrees,}$$

$$0.895/h^{0.912} \text{, for } \alpha = 90 \text{ degrees,}$$

$$1.0, \text{ for } \alpha = 0 \text{ degrees}$$

h , and α based on ASME III, NB-3600

interpolate linearly for values of $\alpha < 90$ degrees, $B2$ not less than 1.0

- 8 $B1 = -0.1 + 0.4h$, but not less than 0.0 nor greater than 0.5. Also, for $B2 = 1.0$, $B1 = 0.5$

$$B2 = 1.3/h^{2/3} \text{ for } \alpha > \text{ or } = 90 \text{ degrees,}$$

$$1.17/h^{0.56} \text{, for } \alpha = 45 \text{ degrees}$$

$$1.0, \text{ for } \alpha = 0 \text{ degrees}$$

h , and α based on ASME III, NB-3600

interpolate linearly for values of $\alpha < 90$ degrees, $B2$ not less than 1.0

- 9 $FCI = 0.75i$, but less than 1.0

$$i = 0.5 + 0.01\alpha(D_2/t_2)^{1/2} \text{, but not greater than 2.0}$$

D_2 , t_2 , and α based on ASME III, NC-3600

- 10 $B1 = 0.5$, except if either $B2b$ or $B2r$ is $4/3$, then $B1 = 2/3$

$$B2b = 0.4(R_m/T_r)^{2/3} \text{, but not less than } 4/3$$

$$B2r = 0.5(R_m/T_r)^{2/3} \text{, but not less than } 4/3$$

R_m and T_r based on ASME III, NB3600

- 11 $FCI = 0.75i$, but not less than 1.0

$$i = 0.9/h^{2/3} \text{, } h \text{ based on ASME III, NC-3600}$$