

SSER

Task: Allegation A-260

Reference No.: 4-84-A-06-142(3)

Characterization: It is alleged that there is a lack of traceability of certain materials used in non-pressure retaining components in the containment vessel such as equipment door handling device, personnel and escape lock hardware, and miscellaneous structures. This allegation is related to Allegation A-258.

Assessment of Allegation: The alleged suggested that in order to resolve the issue of lack of traceability, samples of the materials in question should be taken and mechanical and chemical analyses performed to determine if the materials are acceptable.

The alleged's suggestion is a plausible solution to the issue of traceability of materials. However, the NRC staff determined as a result of its inspections that this concern was satisfactorily resolved with regard to the base metal as described in the NRC staff's assessment of Allegation A-258. However, the issue of traceability of the weld material, process and personnel used in welding the Class D materials inside the containment has not been satisfactorily resolved. The alleged's suggestion has been identified as an option in resolving the issue in Allegation A-259.

This allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. Allegation A-258 and A-259.

Statement Prepared By: J. Strosnider Date

Reviewed By: Team Leader Date

Reviewed By: Site Team Leader(s) Date

Approved By: Task Management Date

8510010241 850614
PDR ADOCK 05000382
E PDR

Document Name:

SSER A-260

Requestor's ID:

CONNIE

Author's Name:

Document Comments:

SSER

Task: Allegation A-260

Reference No.: 4-84-A-06-142(3)

Characterization: This item is related to Allegation A-258 in which it has been alleged that there is a lack of traceability of certain materials used in the containment vessel. The alleged has suggested that in order to resolve the issue of lack of traceability, samples of the materials in question should be taken and mechanical and chemical analyses performed to determine if the materials are acceptable.

Assessment of Allegation: The alleged's suggestion is a plausible solution to the issue of traceability of materials. However, the NRC staff has determined as a result of its inspections that this concern has been satisfactorily resolved as described in the Staff's assessment of Allegation A-258.

④ This allegation has neither safety significance nor generic implications.
Potential Violations: None.

Actions Required: None.

References

1. NRC staff evaluation of Allegation A-258.

non-pressure retaining components in the containment vessel such as equipment door handling device, personnel and escape lock hardware, and miscellaneous structures.
This allegation is related to Allegation 258.

Statement Prepared By:

John Strosnider

Date

Reviewed By:

Team Leader

Date

Reviewed By:

Site Team Leader(s)

Date

Approved By:

Task Management

Date

SSER

Task: Allegation A-260

Reference No.: 4-84-A-06-142(3)

Characterization: It has been alleged that there is a lack of traceability of certain materials used in non-pressure retaining components in the containment vessel such as equipment door handling device, personnel and escape look hardware, and miscellaneous structures. This allegation is related to Allegation A-258.

Assessment of Allegation: The allegor suggested that in order to resolve the issue of lack of traceability, samples of the materials in question should be taken and mechanical and chemical analyses performed to determine if the materials are acceptable.

The allegor's suggestion is a plausible solution to the issue of traceability of materials. However, the NRC staff determined as a result of its inspections that this concern satisfactorily resolved as described in the NRC staff's assessment of Allegation A-258.

This allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. Allegation A-258.

Statement Prepared By:

Jack Strosnider

Date

Reviewed By:

Team Leader

Date

Reviewed By:

Site Team Leader(s)

Date

Approved By:

Task Management

Date

SSER

EXTRA
COPY

Task: Allegation A-260

Reference No.: 4-84-A-06-142(3)

Characterization: It is alleged that there is a lack of traceability of certain materials used in non-pressure retaining components in the containment vessel such as equipment door handling device, personnel and escape lock hardware, and miscellaneous structures. This allegation is related to Allegation A-258.

Assessment of Allegation: The allegor suggested that in order to resolve the issue of lack of traceability, samples of the materials in question should be taken and mechanical and chemical analyses performed to determine if the materials are acceptable.

The allegor's suggestion is a plausible solution to the issue of traceability of materials. However, the NRC staff determined as a result of its inspections that this concern was satisfactorily resolved with regard to the base metal as described in the NRC staff's assessment of Allegation A-258. However, the issue of traceability of the weld material, process and personnel used in welding the Class D materials inside the containment has not been satisfactorily resolved. The allegers suggestion has been identified as an option in resolving the issue in Allegation A-259.

This allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. Allegation A-258 and A-259.

Statement Prepared By:

J. Strosnider

Date

Reviewed By:

Team Leader

Date

Reviewed By:

Site Team Leader(s)

Date

Approved By:

Task Management

Date

Document Name:

SSER A-260

Requestor's ID:

CONNIE

Author's Name:

Document Comments: