

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
15	TECHNICAL SPECIFICATIONS AND BASES	
15.1	Definitions	15.1-1
15.2.0	Safety Limits and Limiting Safety System Settings	15.2.1-1
15.2.1	Safety Limit, Reactor Core	15.2.1-1
15.2.2	Safety Limit, Reactor Coolant System Pressure	15.2.2-1
15.2.3	Limiting Safety System Settings, Protective Instrumentation	15.2.3-1
15.3	Limiting Conditions for Operation	15.3.0-1
15.3.0	General Considerations	15.3.0-1
15.3.1	Reactor Coolant System	15.3.1-1
15.3.2	Chemical and Volume Control System	15.3.2-1
15.3.3	Emergency Core Cooling System, Auxiliary Cooling Systems, Air Recirculation Fan Coolers, and Containment Spray	15.3.3-1
15.3.4	Steam and Power Conversion System	15.3.4-1
15.3.5	Instrumentation System	15.3.5-1
15.3.6	Containment System	15.3.6-1
15.3.7	Auxiliary Electrical Systems	15.3.7-1
15.3.8	Refueling	15.3.8-1
15.3.9	Effluent Releases	15.3.9-1
15.3.10	Control Rod and Power Distribution Limits	15.3.10-1
15.3.11	Movable In-Core Instrumentation	15.3.11-1
15.3.12	Control Room Emergency Filtration	15.3.12-1
15.3.13	Shock Suppressors (Snubbers)	15.3.13-1
15.3.14	Fire Protection System (This section was deleted as of)	15.3.14-1
15.3.15	Overpressure Mitigating System	15.3.15-1
15.3.16	Reactor Coolant System Pressure Isolation Valves	15.3.16-1
15.4	Surveillance Requirements	15.4-1
15.4.1	Operational Safety Review	15.4.1-1
15.4.2	In-Service Inspection of Safety Class Components	15.4.2-1
15.4.3	Primary System Testing Following Opening	15.4.3-1
15.4.4	Containment Tests	15.4.4-1
15.4.5	Emergency Core Cooling System and Containment Cooling System Tests	15.4.5-1
15.4.6	Emergency Power System Periodic Tests	15.4.6-1
15.4.7	Main Steam Stop Valves	15.4.7-1
15.4.8	Auxiliary Feedwater System	15.4.8-1
15.4.9	Reactivity Anomalies	15.4.9-1
15.4.10	Operational Environmental Monitoring	15.4.10-1
15.4.11	Control Room Emergency Filtration	15.4.11-1
15.4.12	Miscellaneous Radioactive Materials Sources	15.4.12-1
15.4.13	Shock Suppressors (Snubbers)	15.4.13-1
15.4.14	Surveillance of Auxiliary Building Crane Lifting Devices	15.4.14-1
15.4.15	Fire Protection System (This section was deleted as of)	15.4.15-1
15.4.16	Reactor Coolant System Pressure Isolation Valves Leakage Tests	15.4.16-1

Unit 1 - Amendment No.

15-i

Unit 2 - Amendment No.

9612240144 961216
PDR ADOCK 05000266
P PDR

15.3.14 FIRE PROTECTION SYSTEM (This section was deleted as of .)

15.4.15

FIRE PROTECTION SYSTEM (This section was deleted as of

.)

|

15.6 ADMINISTRATIVE CONTROLS (Continued)

15.6.2 ORGANIZATION (Continued)

FACILITY STAFF (Continued)

15.6.2.2 (Continued)

- c. At least two licensed Operators shall be present in the control room during reactor start-up, scheduled reactor shutdown and during recovery from reactor trips.
- d. An individual qualified in radiation protection procedures shall be on site when fuel is in either reactor.**
- e. All core alterations shall be directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.

*SRO = NRC Senior Reactor Operator License

RO = NRC Reactor Operator License

** This shift may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence of personnel, provided immediate action is taken to restore the shift makeup to within the minimum requirements.

15.6.4 TRAINING

- 15.6.4.1 A retraining and replacement training program for the facility staff shall be maintained under the direction of the Training Manager and shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and 10 CFR Part 55.

15.6.5 REVIEW AND AUDIT

15.6.5.1 Manager's Supervisory Staff

- 15.6.5.1.1 The Manager's Supervisory Staff (MSS) shall function to advise the Manager on all matters related to nuclear safety.

- 15.6.5.1.2 The Manager's Supervisory Staff shall be selected and designated by the Manager from a list of qualified individuals in the following disciplines:

Operations
Maintenance
Health Physics
Engineering
Licensing
Training
Chemistry

- 15.6.5.1.3 Each individual representing a MSS discipline shall meet or exceed the qualification requirements specified in Section 4.2 of ANSI N18.1-1971, except as described in Specification 15.6.3.2 for the Health Physics Manager.

D. Failure of Containment High-Range Radiation Monitor

A minimum of two in-containment radiation-level monitors with a maximum range of 10^8 rad/hr (10^7 /hr for photons only) should be operable at all times except for cold shutdown and refueling outages. This is specified in Table 15.3.5-5, item 7. If the minimum number of operable channels are not restored to operable condition within seven days after failure, a special report shall be submitted to the NRC within thirty days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to operable status.

E. Failure of Main Steam Line Radiation Monitors

If a main steam line radiation monitor (SA-11) fails and cannot be restored to operability in seven days, prepare a special report within thirty days of the event, outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the channel to operable status.