



**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(203) 447-1791
Fax (203) 444-4277

The Northeast Utilities System

December 13, 1996

Docket No. 50-423
B16028

Re:10CFR 50.73(a)(2)(ii)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 96-047-00
Submitted Pursuant to 10CFR 50.73(a)(2)(ii)

This letter forwards Licensee Event Report 96-047-00, documenting a condition that was determined at Millstone Unit No. 3 on November 14, 1996. This LER is submitted pursuant to 10CFR 50.73(a)(2)(ii). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. James M. Peschel at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



M. H. Brothers
Unit Director, Millstone Unit No. 3

9612260036 961213
PDR ADOCK 05000423
3 PDR

Handwritten: B-22
11

Attachment: 1) NNECO's commitments in response to LER 96-047-00
2) LER 96-047-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 96-047-00)

December 13, 1996

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Any other actions discussed in the submittal represent intended or planned actions by NNECO. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16028-01	The document providing engineering guidance on generic seismic inspection criteria for Unit 3 will be revised to add additional guidance on seismic qualification.	February 5, 1997
B16028-02	Operations, maintenance and the technical support organizations will review procedures to determine evolutions where plant equipment is placed in alternative configurations in which it may not be seismically qualified. Procedures will be revised as necessary to incorporate the results.	April 15, 1997
B16028-03	Training will develop and deliver a program to inform the engineering, operations, and maintenance organizations of seismic qualification requirements.	May 1, 1997
B16028-04	Engineering will work with the switchgear vendor to identify and incorporate (if necessary) any additional seismic restraints for the 4.16 kV safety related switchgear. Storage requirements for racked-down breakers will be reviewed with the vendor.	Prior to startup.