

MONTHLY NARRATIVE REPORT
OF OPERATING
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of July, 1985. This report was prepared by the Plant Staff and is submitted in accordance with Section IX:I.l.c. of the Technical Specifications.

During the report period, the reactor has been in the cold shutdown mode with the core unloaded and the reactor vessel drained. During the month, work continued on the layup of equipment not required by this operating mode, plant decontamination, and preparations for decommissioning. Layup of the steam turbine, condensate and off gas systems were completed. Shipments of solidified radioactive wastes were continued throughout the month of July. No other significant maintenance was accomplished during the month.

8510010414 850731
PDR ADOCK 05000133
R PDR

IE24
1/1

OPERATING DATA REPORT

DOCKET NO 50-133
 DATE AUG 2, 1985
 COMPLETED BY C. C. KLOCK
 TELEPHONE 707/443-2787

OPERATING STATUS

1. Unit Name: HUMBOLDT BAY POWER PLANT - UNIT 3
2. Reporting Period: JULY 1985
3. Licensed Thermal Power (MWt): 220
4. Nameplate Rating (Gross MWe): 65
5. Design Electrical Rating (Net MWe): 65
6. Maximum Dependable Capacity (Gross MWe): 65
7. Maximum Dependable Capacity (Net MWe): 63
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>5087</u>	<u>192862</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>98171</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>97252</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>15,618,456</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,739,732</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,532,971</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>50.4%</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>50.4%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>37.2%</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>36.2%</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>1.91%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: DECOMMISSIONING

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH July

DOCKET NO. 50-133
 UNIT NAME HBP #3
 DATE AUG 2, 1985
 COMPLETED BY CEK/CK
 TELEPHONE 202/443-2787

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licenses Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	744	C, H	I	N/A	—	—	SEISMIC MODIFICATIONS

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH July

DOCKET NO. 50-133
 UNIT NAME HBP #3
 DATE Aug 2, 1985
 COMPLETED BY C. K. S. & C.
 TELEPHONE 202/443-2787

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	744	C, H	I	N/A	—	—	SEISMIC MODIFICATIONS

1 F: Forced
S: Scheduled

2 Reason:

A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3 Method:

1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit I - Same Source

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-133
 UNIT HBPP #3
 DATE AUG. 2, 1985
 COMPLETED BY CCKWICK
 TELEPHONE 707/443-2787

MONTH JULY

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

1034 SIXTH STREET • EUREKA, CALIFORNIA 95501 • (707) 443-2787

E. D. WEEKS

PLANT MANAGER

NUCLEAR PLANT OPERATIONS - HUMBOLDT

August 7, 1985


Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-133
License No. DPR-7

Gentlemen:

Enclosed are the completed monthly report forms and the narrative of operating and major maintenance experience for Humboldt Bay Power Plant Unit No. 3 (HBPP-Unit 3) for July, 1985. These forms and the narrative are submitted in accordance with Section IX I.l.c of our Technical Specifications.

Sincerely,



E. D. Weeks
Plant Manager
Humboldt Bay Power Plant
1034 Sixth Street
Eureka, California 95501
(707-443-2787)

Enclosure

cc: Mr. J. C. Carroll
Mr. B. S. Lew
Mr. J. D. Shiffer

Mr. John B. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

EDWeeks:mc

IE24
11