



Northeast  
Nuclear Energy

Hope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(203) 447-1791  
Fax (203) 444-4277

The Northeast Utilities System

December 13, 1996

Docket No. 50-423

B15967

Re: 10CFR50.73(a)(2)(ii)(B)  
10CFR50.73(a)(2)(v)(B)  
10CFR50.73(a)(2)(v)(D)  
10CFR50.73(a)(2)(vii)(B)  
10CFR50.73(a)(2)(vii)(D)

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Millstone Nuclear Power Station Unit 3  
Licensee Event Report 96-007-02  
Submitted Pursuant to  
10CFR50.73(a)(2)(ii)(B), 10CFR50.73(a)(2)(v)(B&D)  
and 10CFR50.73(a)(2)(vii)(B&D)

This letter forwards Licensee Event Report 96-007-02, supplementing the report that was submitted on May 2, 1996. This LER is submitted pursuant to 10CFR 50.73(a)(2)(ii)(B), 10CFR50.73(a)(2)(v)(B&D) and 10CFR50.73(a)(2)(vii)(B&D). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. James M. Peschel at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
M. H. Brothers  
Unit Director, Millstone Unit No. 3

9612260156 961213  
PDR ADOCK 05000423  
S PDR

*Handwritten initials and date:*  
12/22/96  
11

Attachment: 1) NNECO's commitments in response to LER 96-007-02  
2) LER 96-007-02

cc: H. J. Miller, Region I Administrator  
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3  
V. L. Rooney, NRC Project Manager, Millstone Unit No. 3  
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423  
B15967

Attachment 1

Millstone Nuclear Power Station, Unit No. 3  
NNECO's Commitments  
In Response To  
(LER 96-007-02)

December 13, 1996

Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Any other actions discussed in the submittal represent intended or planned actions by NNECO. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

| Number    | Commitment  | Due Date   |
|-----------|---|--|
| B15847-01 | The design reviews of the RSS, QSS, and SI piping systems will be completed and the design modifications required to restore the systems to design basis requirements will be completed.  | prior to declaring the systems operable for other than mode 5 and 6. |
| B15847-02 | A review of those systems which would be exposed to a Post-LOCA or Post HELB environment and which are required to mitigate the consequences of a design basis accident will be performed to determine whether or not they are susceptible to the same types of design deficiencies, and to ensure the systems comply with the design basis requirements. | prior to entry into Mode 4   |

| Number    | Commitment   | Due Date                   |
|-----------|--|----------------------------|
| B15967-01 | The plant's Stress Data Package (SDPs)s will be reviewed, and corrected                              | prior to entry into Mode 4 |
| B15967-02 | The updated SDPs will be added to the controlled documents list following completion of the reviews. | prior to entry into Mode 4 |