



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUL 11 1985

Docket Nos.: 50-440
and 50-441

Mr. Murray R. Edelman, Vice President
Nuclear Operations Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: CEI's Conformance with Regulatory Guides 1.52, 1.140 and 1.143 -
Perry Nuclear Power Plant, Units 1 and 2

The NRC staff has reviewed responses provided with your letter dated June 18, 1985 relative to the subject regulatory guides, (in response to the staff's questions transmitted by my letter dated May 20, 1985). As a result of that review, the following information is required:

1. Since CEI does not plan to utilize the UNI system to solidify Perry radwastes, the conclusions documented in Section 11.4 of the Perry SER (NUREG-0887) are no longer valid. Therefore, CEI is requested to submit information on the mobile system which will be used for this purpose, in sufficient detail to satisfy the acceptance criteria of Section 11.4 of the Standard Review Plan (NUREG-0800). The mobile system and CEI's Process Control Program will have to be approved by the NRC prior to solidification of any waste.
2. CEI indicates that portions of the liquid radwaste system were declassified from Safety Class 3 to a non-safety class. It is the staff's position that the liquid radwaste components should be Quality Group D as identified in Regulatory Guide 1.26, and should meet the requirements of Table 1 of Regulatory Guide 1.143. CEI's response to the staff's position is requested.

8507190154 850711
PDR ADOCK 05000440
A PDR

Mr. Murray R. Edelman

- 2 -

JUL 11 1985

Until the above listed information is received and the subject matter resolved, you should consider conformance to the subject regulatory guides to be an outstanding open issue for Perry licensing. If not resolved by the time the next Perry SER supplement, this issue will be identified as such therein. If there are any questions, please direct them to the Project Manager, Mr. John J. Stefano at (301) 492-7037.

Sincerely,

ORIGINAL SIGNED BY:

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

cc: See next page

DISTRIBUTION:

<u>Docket File</u>	JStefano	CWillis
NRC PDR	OELD	JHayes
LPDR	ACRS (16)	RKnop
NSIC	EJordan	RLanksbury
PRC System	JPartlow	
LB#1 R/F	BGrimes	
MRushbrook	WGammill	

LB#1:DL
JStefano:kab
07/18/85

LB#1:DL
BJYoungblood
07/11/85

JUL 11 1985

Mr. Murray R. Edelman
The Cleveland Electric
Illuminating Company

Perry Nuclear Power Plant
Units 1 and 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Mr. Larry O. Beck
The Cleveland Electric
Illuminating Company
P. O. Box 97 E-210
Perry, Ohio 44081

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047