

PROPOSED TECHNICAL SPECIFICATION CHANGES

9612260234 961219
PDR ADOCK 05000368
P PDR

INDEX

DESIGN FEATURES

<u>SECTION</u>	<u>PAGE</u>
<u>5.1 SITE</u>	
Exclusion Area.....	5-1
Low Population Zone.....	5-1
<u>5.2 CONTAINMENT</u>	
Configuration.....	5-1
Design Pressure and Temperature.....	5-4
<u>5.3 REACTOR CORE</u>	
Fuel Assemblies.....	5-4
Control Element Assemblies.....	5-4
<u>5.4 REACTOR COOLANT SYSTEM</u>	
Design Pressure and Temperature.....	5-4
<u>5.5 METEOROLOGICAL TOWER LOCATION.....</u>	5-5
<u>5.6 FUEL STORAGE</u>	
Criticality-Spent Fuel.....	5-5
Criticality-New Fuel.....	5-5
Drainage.....	5-5
Capacity.....	5-5
<u>5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS.....</u>	5-5

DESIGN FEATURES

5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

5.6 FUEL STORAGE

CRITICALITY - SPENT FUEL

5.6.1.1 The spent fuel racks are designed and shall be maintained so that the calculated effective multiplication factor is no greater than 0.95 (including all known uncertainties) when the pool is flooded with unborated water.

CRITICALITY - NEW FUEL

5.6.1.2 The new fuel storage racks are designed and shall be maintained with a nominal 25.0 inch center-to-center distance between new fuel assemblies such that K_{eff} will not exceed 0.98 when fuel having a maximum enrichment of 4.1 weight percent U-235 is in place and aqueous foam moderation is assumed and K_{eff} will not exceed 0.95 when the storage area is flooded with unborated water. The calculated K_{eff} includes a conservative allowance of 2.1% $\Delta k/k$ for uncertainties.

DRAINAGE

5.6.2 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 399' 10 1/2".

CAPACITY

5.6.3 The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 988 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.

MARKUP OF CURRENT ANO-2 TECHNICAL SPECIFICATIONS

(FOR INFO ONLY)

INDEX

DESIGN FEATURES

<u>SECTION</u>	<u>PAGE</u>
<u>5.1 SITE</u>	
Exclusion Area.....	5-1
Low Population Zone.....	5-1
<u>5.2 CONTAINMENT</u>	
Configuration.....	5-1
Design Pressure and Temperature.....	5-4
<u>5.3 REACTOR CORE</u>	
Fuel Assemblies.....	5-4
Control Element Assemblies.....	5-4
<u>5.4 REACTOR COOLANT SYSTEM</u>	
Design Pressure and Temperature.....	5-4
Volume.....	5-5
<u>5.5 METEOROLOGICAL TOWER LOCATION.....</u>	5-5
<u>5.6 FUEL STORAGE</u>	
Criticality-Spent Fuel.....	5-5
Criticality-New Fuel.....	5-5
Drainage.....	5-5
Capacity.....	5-5
<u>5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS.....</u>	5-5

DESIGN FEATURES

VOLUME

~~5.4.2 The total water and steam volume of the reactor coolant system is 10,295 ± 400 cubic feet at a nominal T_{avg} of 545°F.~~

5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

5.6 FUEL STORAGE

CRITICALITY - SPENT FUEL

5.6.1.1 The spent fuel racks are designed and shall be maintained so that the calculated effective multiplication factor is no greater than 0.95 (including all known uncertainties) when the pool is flooded with unborated water.

CRITICALITY - NEW FUEL

5.6.1.2 The new fuel storage racks are designed and shall be maintained with a nominal 25.0 inch center-to-center distance between new fuel assemblies such that K_{eff} will not exceed 0.98 when fuel having a maximum enrichment of 4.1 weight percent U-235 is in place and aqueous foam moderation is assumed and K_{eff} will not exceed 0.95 when the storage area is flooded with unborated water. The calculated K_{eff} includes a conservative allowance of 2.1% $\Delta k/k$ for uncertainties.

DRAINAGE

5.6.2 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 399' 10½".

CAPACITY

5.6.3 The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 988 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.