

PROPOSED TECHNICAL SPECIFICATION CHANGES

9612260238 961219  
PDR ADOCK 05000368  
P PDR

ADMINISTRATIVE CONTROL

CORE OPERATING LIMITS REPORT

- 9) "CESEC-Digital Simulation of a Combustion Engineering Nuclear Steam Supply System," December 1981 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for CEA Position, 3.1.3.6 for Regulating CEA and Group P Insertion Limits, and 3.2.4.b for DNBR Margin).
- 10) "Technical Manual for the CENTS Code," CENPD 282-P-A, February 1991 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for CEA Position, 3.1.3.6 for Regulating and Group P Insertion Limits, and 3.2.4.b for DNBR Margin).
- 11) Letter: O.D. Parr (NRC) to F.M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for 6.9.5.1.4, 6.9.5.1.5, and 6.9.5.1.8 methodologies.
- 12) Letter: O.D. Parr (NRC) to A.E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model changes). NRC approval for 6.9.5.1.6 methodology.
- 13) Letter: 2CNA038403, dated March 20, 1984, J.R. Miller (NRC) to J.M. Griffin (AP&L), "CESEC Code Verification." NRC approval for 6.9.5.1.9 methodology.

6.9.5.2 The core operating limits shall be determined so that all applicable limits (e.g. fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

6.9.5.3 The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

MARKUP OF CURRENT ANO-2 TECHNICAL SPECIFICATIONS

(FOR INFO ONLY)

ADMINISTRATIVE CONTROL

CORE OPERATING LIMITS REPORT

- 9) "CESEC-Digital Simulation of a Combustion Engineering Nuclear Steam Supply System," December 1981 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for ~~Movable Control Assemblies~~ CEA Position, 3.1.3.6 for Regulating CEA and Group P Insertion Limits, and 3.2.4.b for DNBR Margin).

- 10) "Technical Manual for the CENTS Code," CENPD 282-P-A, February 1991 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for CEA Position, 3.1.3.6 for Regulating and Group P Insertion Limits, and 3.2.4.b for DNBR Margin.

- 101) Letter: O.D. Parr (NRC) to F.M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for 6.9.5.1.4, 6.9.5.1.5, and 6.9.5.1.8 methodologies.

- 112) Letter: O.D. Parr (NRC) to A.E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model changes). NRC approval for 6.9.5.1.6 methodology.

- 123) Letter: 2CNA038403, dated March 20, 1984, J.R. Miller (NRC) to J.M. Griffin (AP&L), "CESEC Code Verification." NRC approval for 6.9.5.1.9 methodology.

6.9.5.2 The core operating limits shall be determined so that all applicable limits (e.g. fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

6.9.5.3 The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

PROPOSED TECHNICAL SPECIFICATION CHANGES SHOULD SBLOCA  
AMENDMENT BE APPROVED PRIOR TO THIS REQUEST

ADMINISTRATIVE CONTROL

CORE OPERATING LIMITS REPORT

- 10) "CESEC-Digital Simulation of a Combustion Engineering Nuclear Steam Supply System," December 1981 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for CEA Position, 3.1.3.6 for Regulating CEA and Group P Insertion Limits, and 3.2.4.b for DNBR Margin).
- 11) "Technical Manual for the CENTS Code," CENPD 282-P-A, February 1991 (Methodology for Specifications 3.1.1.1 and 3.1.1.2 for Shutdown Margin, 3.1.1.4 for MTC, 3.1.3.1 for CEA Position, 3.1.3.6 for Regulating and Group P Insertion Limits, and 3.2.4.b for DNBR Margin).
- 12) Letter: O.D. Parr (NRC) to F.M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for 6.9.5.1.4, 6.9.5.1.5, and 6.9.5.1.8 methodologies.
- 13) Letter: O.D. Parr (NRC) to A.E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model changes). NRC approval for 6.9.5.1.6 methodology.
- 14) Letter: K. Kniel (NRC) to A.E. Scherer (CE), dated September 27, 1977 (Evaluation of Topical Reports CENPD-133, Supplement 3-P and CENPD-137, Supplement 1-P). NRC approval for 6.9.5.1.9 methodology.
- 15) Letter: 2CNA038403, dated March 20, 1984, J.R. Miller (NRC) to J.M. Griffin (AP&L), "CESEC Code Verification." NRC approval for 6.9.5.1.10 methodology.

6.9.5.2 The core operating limits shall be determined so that all applicable limits (e.g. fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and accident analysis limits) of the safety analysis are met.

6.9.5.3 The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.