

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

SHIELDS L. DALTROFF
VICE PRESIDENT
ELECTRIC PRODUCTION

(215) 841-5001

June 17, 1985

DOCKETED
USNRC

Docket No. 50-352~~01~~

'85 JUN 21 A10:50

Mr. Richard W. Starostecki, Director
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

Dear Mr. Starostecki:

This letter provides information related to the incorporation of environmental qualification requirements into the Limerick Preventive Maintenance Program as discussed in NRC Region I Inspection Report 50-352/85-03 (OAT), Item 9.

This information was requested by Mr. Robert M. Gallo of your staff during a telephone conversation with Mr. John Franz, Limerick Generating Station Superintendent - Operations, on June 12, 1985.

The Engineering and Research Department has provided environmental qualification reports identifying those mechanical and electrical maintenance requirements which need to be addressed by the preventative maintenance program including such things as valve seat ring and stem packing replacement, valve diaphragm replacement, checking of electrical connections, and replacement of solenoid valves. These requirements are currently being inputted into the Computerized History and Maintenance Planning System (CHAMPS) computer. This system will automatically schedule the necessary work and provide tracking of the maintenance activities. The inputting of these requirements will be completed prior to the first refueling outage. Those requirements identified as having a frequency such that they should be performed before the first refueling outage will be entered into CHAMPS or manually tracked prior to their due date to assure that they will be completed.

Mr. Richard W. Starostecki

June 17, 1985

Page 2

Should you require additional information, please do not
hesitate to contact us.

Very truly yours,

Original signed by

S. L. DALTROFF

cc: LGS Resident Site Inspector
See Attached Service List

cc: Judge Helen F. Hoyt
Judge Jerry Harbour
Judge Richard F. Cole
Troy B. Conner, Jr., Esq.
Ann P. Hodgdon, Esq.
Mr. Frank R. Romano
Mr. Robert L. Anthony
Ms. Phyllis Zitner
Charles W. Elliott, Esq.
Zori G. Ferkin, Esq.
Mr. Thomas Gerusky
Director, Penna. Emergency Management Agency
Angus Love, Esq.
David Wersan, Esq.
Robert J. Sugarman, Esq.
Kathryn S. Lewis, Esq.
Spence W. Perry, Esq.
Jay M. Gutierrez, Esq.
Atomic Safety & Licensing Appeal Board
Atomic Safety & Licensing Board Panel
Docket & Service Section
James Wiggins
Timothy R. S. Campbell

June 12, 1985