

YANKEE ATOMIC NUCLEAR POWER STATION
MONTHLY STATISTICAL REPORT 85-07
FOR THE MONTH OF JULY 1985

8510010649 850731
PDR ADOCK 05000029
R PDR

TC24
1/1

OPERATING DATA REPORT

DOCKET NO. 50-29
 DATE 850802
 COMPLETED BY S. WHIPPLE
 TELEPHONE (617) 872-8100

OPERATING STATUS

1. Unit Name: Yankee Rowe
2. Reporting Period: July, 1985
3. Licensed Thermal Power (MMt): 600
4. Nameplate Rating (Gross MWe): 185
5. Design Electrical Rating (Net MWe): 175
6. Maximum Dependable Capacity (Gross MWe): 180
7. Maximum Dependable Capacity (Net MWe): 167
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted. If Any (Net MWe):

10. Reasons For Restrictions. If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.00	5,087.00	---
12. Number of Hours Reactor Was Critical	744.00	5,087.00	173,010.10
13. Reactor Reserve Shutdown Hours	0.00	0.00	0.00
14. Hours Generator On-Line	744.00	5,087.00	168,271.42
15. Unit Reserve Shutdown Hours	0.00	0.00	0.00
16. Gross Thermal Energy Generated (MMH)	445,455.00	2,994,642.00	91,485,294.52
17. Gross Electrical Energy Generated (MMH)	134,122.90	908,036.60	27,726,839.90
18. Net Electrical Energy Generated (MMH)	125,826.47	851,420.66	25,945,971.11
19. Unit Service Factor	100.00	100.00	77.66
20. Unit Availability Factor	100.00	100.00	77.66
21. Unit Capacity Factor (Using MDC Net)	101.27	100.22	73.68
22. Unit Capacity Factor (Using DER Net)	96.64	95.64	70.22
23. Unit Forced Outage Rate	0.00	0.00	5.32
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Core XVIII Refueling - October 19, 1985 - 6 weeks			

25. If Shutdown At End of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-29
UNIT YANKEE ROWE
DATE 850802
COMPLETED BY S. WHIPPLE
TELEPHONE (617) 872-8100

MONTH JULY, 1985

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	170.0
2	170.1
3	170.1
4	170.1
5	169.8
6	169.5
7	169.1
8	169.1
9	169.5
10	169.5
11	169.5
12	169.5
13	169.7
14	169.2
15	168.9
16	169.2

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	169.3
18	169.1
19	168.7
20	168.4
21	167.9
22	167.7
23	167.8
24	167.9
25	168.6
26	168.9
27	169.3
28	168.6
29	168.8
30	169.4
31	169.8

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JULY, 1985

DOCKET NO. 50-29

UNIT YANKEE ROWE

DATE 850802

COMPLETED BY S. WHIPPLE

TELEPHONE (617) 872-8100

No.	Date	1 Type	Duration (Hours)	2 Reason	Method Of Shutting Down Reactor	Licensee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
-----	------	-----------	---------------------	-------------	---------------------------------------	-------------------------------	------------------	---------------------	---

NONE

1	2	3	4
F: Forced	Reason:	Method:	Exhibit 6-Instructions
S: Scheduled	A-Equipment Failure (Explain)	1-Manual	for Preparation of Data
	B-Maintenance or Test	2-Manual Scram.	Entry Sheets for License
	C-Refueling	3-Automatic Scram.	Event Report (LER) File
	D-Regulatory Restriction	4-Other (Explain)	(NUREG-0161)
	E-Operator Training & Licensed Examination		
	F-Administrative		5
	G-Operational Error (Explain)		Exhibit 1 - Same Source
	H-Other (Explain)		

DOCKET NO.	50-29
UNIT	YANKEE ROWE
DATE	850802
COMPLETED BY	S. WHIPPLE
TELEPHONE	(617) 872-8100

REPORT MONTH JULY, 1985

SUMMARY OF OPERATING EXPERIENCES

Full Power Operation - All Month

YANKEE ATOMIC ELECTRIC COMPANY

Telephone (617) 872-8100
TWX 710-380-7619

1671 Worcester Road, Framingham, Massachusetts 01701

August 2, 1985

17.R.4.2
FYR 85-81

United States Nuclear Regulatory Commission
Director, Office of Management Information
and Program Control
Washington, D.C. 20555

Dear Sir:

Submitted herewith is the Monthly Statistical Report for the Yankee Atomic Power Station for the month of July 1985.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY



L. H. Heider
Vice President/Manager of Operations

LHH/ba

cc: Region I
Office of Inspection and Enforcement

IE24
11