

SSER

Task: Allegation A-182

Ref. No.: 4-84-A-06/77

Characterization: It is alleged that welding performed by J. A. Jones Construction Company on structural items such as pipe hangers or supports for heating, ventilating and air conditioning systems has not been inspected.

Assessment of Allegation: In reviewing this allegation, the NRC staff found that the J. A. Jones QA project manager had submitted a letter to EBASCO Services on January 12, 1981, listing all incomplete inspections that needed to be completed by EBASCO Force account, including welding, as of that date.

Based on a discussion between the NRC staff and the J. A. Jones QA project manager, the NRC staff believes there were no items which had not been inspected by J. A. Jones or EBASCO which did not appear on the list. The letter had listed all structural items both non-safety and safety-related that had incomplete inspections. The NRC staff reviewed all EBASCO safety-related process control sheets (PCS) and travelers, and found no discrepancies. This review substantiated that the work and related documentation is now complete.

The NRC staff concludes that this allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. Letter from J. R. Pertuit (J. A. Jones QA Manager) to R. A. Hartnett (EBASCO), dated January 12, 1981.
2. PCS #36 and #37.
3. PCS #13 and #14.
4. Memo from Bill Yaeger to Cal Griggs, dated July 29, 1980.

*Superseded by Rev. 3  
6/25/84*

Statement Prepared By:

Claude E. Johnson

Date \_\_\_\_\_

Reviewed By:

Team Leader

Date \_\_\_\_\_

Reviewed By:

Site Team Leader(s)

Date \_\_\_\_\_

Approved By:

## Task Management

Date \_\_\_\_\_

SSER

FINAL

Task: Allegation A-182

Ref. No.: 4-84-A-06/77

Characterization: It is alleged that welding performed by J. A. Jones Construction Company on structural items such as pipe hangers or supports for heating, ventilating and air conditioning systems has not been inspected.

Assessment of Allegation: In reviewing this allegation, the NRC staff found that the J. A. Jones QA project manager had submitted a letter to EBASCO Services on January 12, 1981, listing all incomplete inspections that needed to be completed by EBASCO Force account, including welding, as of that date.

Based on a discussion between the NRC staff and the J. A. Jones QA project manager, the NRC staff <sup>FOUND THAT ALL</sup> believes <sup>THAT APPEARED ON THE LIST</sup> there were no items which had not been inspected by J. A. Jones or EBASCO <sup>stet.</sup> which did not appear on the list. The letter ~~had~~ listed all structural items, both non-safety and safety-related, that had incomplete inspections. The NRC staff reviewed all EBASCO safety-related process control sheets (PCS) and travelers, and found no discrepancies. This review substantiated that the work and related documentation is now complete.

The NRC staff concludes that this allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. Letter from J. R. Pertuit (J. A. Jones QA Manager) to R. A. Hartnett (EBASCO), dated January 12, 1981.
2. PCS #36 and #37.
3. PCS #13 and #14.
4. Memo from Bill Yaeger to Cal Griggs, dated July 29, 1980.

Statement Prepared By:

Claude E. Johnson

Date

Reviewed By:

Team Leader

Date

Reviewed By:

Site Team Leader(s)

Date

Approved By:

Task Management

Date

Document Name:  
SSER A-182 *file*

Requestor's ID:  
CONNIE

Author's Name:  
Claude Johnson

Document Comments:

*FINAL*  
*REV-2*