



Entergy Operations, Inc.
P.O. Box B
Killona, LA 70066
Tel 504 739 6242

James J. Fisicaro
Director
Nuclear Safety
Waterford 3

W3F1-96-0215
A4.05
PR

December 26, 1996

U.S. Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Revised Technical Specification Change Request NPF-38-172

Gentlemen:

By letter dated November 7, 1995 and supplemented by letter dated July 17, 1996, Waterford 3 proposed a change to Technical Specification (TS) 3/4.8.1 "Electrical Power Systems - AC Sources" and the associated TS BASES. Additionally, a Basis change was submitted in Letter W3F1-95-0116, dated July 26, 1995.

During telephone conversations with the Staff on October 7 and December 4, 1996, the following changes were discussed (Note that these latest changes are double barred in the attachment):

- 1) Delete "(60 \pm 1.2 Hz)" from TS 4.8.1.1.2.a.4 and reword for clarity.
- 2) Ac'd verbiage to the Basis of TS 3/4.8.1, 3/4.8.2, and 3/4.8.3 to provide clarification of the 10 second time requirement of TS 4.8.1.1.2.a.4 and add monitoring and trending of time to reach steady state voltage and frequency.

The enclosed changes supplement the previous submittals listed above. Only the pages affected by this latest revision are included. Please replace the affected pages with the attached. This submittal provides editorial changes relating to the subject proposed change. This additional information has no affect on the previously provided no significant hazards determination.

9612310152 961226
PDR ADOCK 05000382
P PDR

A001/1

Revised Technical Specification Change Request NPF-38-172


W3F1-96-0215

Page 2

December 26, 1996

Should you have any questions or comments concerning this request, please contact Mr. Paul Caropino at (504)739-6692.

Very truly yours,

Handwritten signature of J. J. Fisicaro in cursive, with the word "for" written below it.

J. J. Fisicaro
Director
Nuclear Safety

JJF/CWT/s:f

Attachment: Revised NPF-38-172

cc: E.W. Merschoff, NRC Region IV
C.P. Patel, NRC-NRR
R.B. McGehee
N.S. Reynolds
NRC Resident Inspectors Office
Administrator Radiation Protection Division
(State of Louisiana)
American Nuclear Insurers