



Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499
TELEPHONE (402) 564-8561

NLS8500192
July 30, 1985

Director, Nuclear Reactor Regulation
Operating Reactors Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Domenic B. Vassallo, Chief

Dear Mr. Vassallo:

Subject: Generic Letter 83-28, Item 3.1.3 "Post Maintenance Testing" (Reactor Trip System Components)
Cooper Nuclear Station NRC Docket No. 50-298, DPR-46

- References: 1) Generic Letter 83-28 "Required Actions Based on Generic Implications of Salem ATWS Events"
- 2) Letter from L. G. Kuncel to D. G. Eisenhut dated November 4, 1983, "Response to Generic Letter 83-28, 'Required Actions Based on Generic Implications of Salem ATWS Events'".

Reference 2 was the District's detailed response to Reference 1. During recent discussions with the staff, the District was informed that the staff required additional information pertaining to action item 3.1.3 of Reference 1. The District had originally interpreted Reference 1 to require no documentation pertinent to this action item, hence Reference 2 did not address the item directly.

In response to the staff's request, the District Nuclear Licensing Department has conducted a review of existing Cooper Nuclear Station (CNS) Technical Specifications in an effort to identify any post-maintenance test requirements which could be demonstrated to degrade rather than enhance safety for both the reactor trip system and all other safety-related components.

Utilization of the word-search capability for the CNS Technical Specifications was made in order to identify all instances where references to post-maintenance testing occurred. A thorough Licensing review of all such references revealed no post-maintenance test requirements which would clearly degrade rather than enhance safety.

Please contact me should you have any further questions.

Sincerely,

J. M. Pilant
Manager, Technical Staff
Nuclear Power Group

LRB:rg

8508060133 5/30/85
PDR ADOCK 5/30/85
P PDR

A055
10