



GPU Nuclear Corporation

Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

September 30, 1985

Director
Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request No. 141

In accordance with 10CFR50.90 and 10CFR50.91, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16, requests a change to Appendix A of that license.

The subject Technical Specification Change Request addresses the replacement of two sets of non-environmentally qualified indicating pressure switches with non-indicating switches that are environmentally qualified. This change will revise Table 4.1.1 of the Technical Specifications. An implementation date of prior to start-up from Maintenance Outage 10M, presently scheduled for October 1985, is requested.

This Technical Specification Change Request has been reviewed and approved by Responsible Technical and Independent Safety Reviewers in accordance with Technical Specification section 6.5.


A check for \$150.00 to cover the fee required for the review of our application for this Technical Specification Change Request is attached.

8510070474 850930
PDR ADOCK 05000219
PDR

*Acc'd w/ check \$150
11/19/85 #191904*

If there are any questions or comments, please contact Brenda Hohman,
Licensing Engineer at (609)971-4642.

Very truly yours,



Peter B. Fiedler
Vice President and Director
Oyster Creek

PBF/BH/dam(0099A)
Enclosures

cc: Dr. Thomas E. Murley, Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station

Mr. Jack N. Donohew, Jr.
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue, Phillips Bldg.
Bethesda, MD 20014
Mail Stop No. 314


OYSTER CREEK NUCLEAR GENERATING STATION

PROVISIONAL OPERATING
LICENSE NO. DPR-16


TECHNICAL SPECIFICATION
CHANGE REQUEST NO. 141
DOCKET NO. 50-219

Applicant submits by this Technical Specification Change Request No. 141 to the Oyster Creek Nuclear Generating Station Technical Specifications, revising Table 4.1.1.

By: _____


Peter B. Fiedler
Vice President and Director
Oyster Creek

Sworn and subscribed to before me this 30th day of September 1985.



A Notary Public of NJ
DIANA A. MALDET
A Notary Public of New Jersey
My Commission Expires June 5, 1986

(0099A)

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)
)
GPU NUCLEAR CORPORATION)


DOCKET NO. 50-219

CERTIFICATE OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 141 for the Oyster Creek Nuclear Generating Station Technical Specifications, filed with the United States Nuclear Regulatory Commission on September 30, 1985, has this day of September 30, 1985, been served on the Mayor of Lacey Township, Ocean County, New Jersey by deposit in the United States mail, addressed as follows:

The Honorable Thomas R. Waskovich
Mayor of Lacey Township
818 West Lacey Road
Forked River, NJ 08731

By


Peter B. Fiedler
Vice President and Director
Oyster Creek

DATED: September 30, 1985

(0099A)