

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company  
Catawba 1

Docket No. 50-413  
License No. NPF-35

The following violations were identified during an inspection conducted on May 9, 1985. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50 Appendix B, Criterion V, as implemented by Section 17.2.5 of the accepted QA Program, requires that activities associated with nuclear safety-related structures, systems and components be accomplished in accordance with procedures appropriate to the activities being performed. Station Directive 3.11.1, Housekeeping and Cleanliness Levels In Safety Related Areas, Revision 9, requires all dirt and debris be removed from a Cleanliness Level IV Area.

Contrary to the above, on May 9, 1985, all dirt and debris including flammable material was not removed from a Level IV Area (Diesel Generator Room 1B).

This is a Severity Level IV violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: JUL 12 1985