

Appendix

NOTICE OF VIOLATION

Wisconsin Electric Power Company

Docket No. 50-266

Docket No. 50-301

As a result of the inspection conducted on June 24-27 and July 3 and 18, 1985, and in accordance with the General Policy and Procedures for NRC Enforcement Actions (10 CFR Part 2, Appendix C), the following violation was identified:

10 CFR 20.201(b) requires that each licensee make such surveys as may be necessary to comply with all sections of Part 20. As defined in 10 CFR 20.201(a), "survey" means an evaluation of the radiation hazards incident to the production, use, release, disposal, or presence of radioactive materials or other sources of radiation under a specific set of conditions.


Contrary to the above, as of the day of the inspection the licensee failed to make such surveys as were necessary to (1) determine that individuals entering containment were not exposed to airborne concentrations exceeding the limits specified 10 CFR 20.103, "Exposure of Individuals to Concentrations of Radioactive Materials in an Unrestricted Area" and (2) assure compliance with 10 CFR 20.106, "Radioactivity in Effluents to Unrestricted Areas." Specifically, the licensee failed to make adequate surveys of airborne concentrations for iodines (present in both restricted and unrestricted areas) when the charcoal adsorbers were analyzed on Detector 1 which was improperly calibrated by a factor of three.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated

August 1, 1985


J. A. Hind, Director
Division of Radiation Safety
and Safeguards