

L I C E N S E E E V E N T R E P O R T ( L E R )

FACILITY NAME (1) Arkansas Nuclear One, Unit One DOCKET NUMBER (2) PAGE (3)  
0151010101 31 11 310F1011  
TITLE (4) Failure to Perform High Range Containment Radiation Monitor Surveillance

EVENT DATE (5)			LER NUMBER (6)		REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
Month	Day	Year	Sequential Number	Revision Number	Month	Day	Year	Facility Names	Docket Number(s)
01	06	1981	01	01	01	07	21	ANO - Unit Two	0151010101 31 61 8

OPERATING MODE (9) 1 THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

POWER	<input type="checkbox"/>	20.402(b)	<input type="checkbox"/>	20.405(c)	<input type="checkbox"/>	50.73(a)(2)(iv)	<input type="checkbox"/>	73.71(b)
LEVEL	<input type="checkbox"/>	20.405(a)(1)(f)	<input type="checkbox"/>	50.36(c)(1)	<input type="checkbox"/>	50.73(a)(2)(v)	<input type="checkbox"/>	73.71(c)
(10) 11010	<input type="checkbox"/>	20.405(a)(1)(ii)	<input type="checkbox"/>	50.36(c)(2)	<input checked="" type="checkbox"/>	50.73(a)(2)(vii)	<input type="checkbox"/>	Other (Specify in
	<input type="checkbox"/>	20.405(a)(1)(iii)	<input checked="" type="checkbox"/>	50.73(a)(2)(i)	<input type="checkbox"/>	50.73(a)(2)(viii)(A)	<input type="checkbox"/>	Abstract below and
	<input type="checkbox"/>	20.405(a)(1)(iv)	<input type="checkbox"/>	50.73(a)(2)(ii)	<input type="checkbox"/>	50.73(a)(2)(viii)(B)	<input type="checkbox"/>	in Text, NRC Form
	<input type="checkbox"/>	20.405(a)(1)(v)	<input type="checkbox"/>	50.73(a)(2)(iii)	<input type="checkbox"/>	50.73(a)(2)(x)	<input type="checkbox"/>	366A)

LICENSEE CONTACT FOR THIS LER (12)  
Name Dwight J. Johnson, Plant Licensing Engineer Telephone Number  
Area  
Code  
51011916141-1311010

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)									
Cause	System	Component	Manufacturer	Reportable to NPRDS	Cause	System	Component	Manufacturer	Reportable to NPRDS

SUPPLEMENT REPORT EXPECTED (14) EXPECTED SUBMISSION DATE (15) Month Day Year  
Yes (If yes, complete Expected Submission Date) No

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

As a result of a verification check of the Station Master Test Control List against the Units 1 and 2 Technical Specifications (T.S.) it was determined that the monthly channel functional test of the high range containment radiation monitors per Unit 1 T.S. 4.1 Table 4.1-1 Item 57 and Unit 2 T.S. 4.3.3.1 Table 4.3-3 Item 1.b, had not been performed since the issuance of amendments to the Technical Specifications on January 31, 1985. The delay in implementation of these specifications was due to a misunderstanding regarding the status of amendments received from the NRC with several errors contained in the text and requirements of the amendments and by delays in implementation of the procedures required for surveillance performance once corrected amendments were received from the NRC on May 3, 1985. Upon discovery of this inconsistency, the required channel functional checks were performed. Actions taken to preclude recurrence of this type event will include improved administrative coordination and tracking by the Plant Licensing group regarding notification of appropriate facility staff and implementation of Technical Specification amendments.



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

July 25, 1985

1CAN078510


U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Licensee Event Report  
No. 85-006-00

Gentlemen:

In accordance with 10CFR50.73(a)(2)(i) and 10CFR50.73(a)(2)(iii), attached is the subject report concerning the failure to perform high range containment radiation monitor surveillance.

Very truly yours,



J. Ted Enos  
Manager, Licensing

JTE:RJS:ds

Attachment

cc: Mr. Richard C. DeYoung  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Norman M. Haller, Director  
Office of Management & Program Analysis  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555