

October 11, 1985

Docket No. 50-344

PDR
014

Mr. Bart D. Withers
Vice President Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Withers:

SUBJECT: SAFETY EVALUATION FOR GENERIC LETTER 83-28 ITEMS 3.1.1 AND 3.1.2

The staff has completed its review of your response to Generic Letter 83-28, Item 3.1.1, Post-Maintenance Testing to Verify Operability, and Item 3.1.2, Review of Test Recommendations and Guidance for the reactor trip system components. The staff's safety evaluation (SE) is enclosed.

The staff concludes that, based on the confirmation that post-maintenance testing is required for safety related equipment and that such testing ensures the equipment is capable of performing its safety function prior to return to service, PGE has satisfied the actions requested by Item 3.1.1. In addition, the staff finds that PGE has reviewed Westinghouse guidance on post-maintenance operability testing and determined that the facility procedures include, or are being revised to include, the guidance required to demonstrate post-maintenance operability of the reactor trip system and therefore satisfies the actions requested by Item 3.1.2.

Sincerely,

/S/

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Distribution:	Docket File	PKreutzer	ACRS 10	
	NRC & L PDRs	LLazo	GZwetzig	Branch Files
	EJordan	OELD	JPartlow	HThompson
	BGrimes			

ORB#3:DL
PKreutzer
10/11/85

ORB#3:DL
LLazo;ef
10/10/85

ORB#3:DL
EButcher
10/11/85

8510180141 851011
PDR ADOCK 05000344
PDR

Mr. Bart D. Withers
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

William T. Dixon
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
Office of Executive Director for Operations
1450 Maria Lane, Suite 210
Walnut Creek, California 94596