



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-103

(412) 787-5141

(412) 923-1960

Telecopy (412) 787-2629

July 12, 1985

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

ATTENTION: Dr. Thomas E. Murley
Administrator

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
System Controls and York Electrical Equipment
Significant Deficiency Report No. 84-04, Final Report

Gentlemen:

This final report is in reference to the potentially reportable Significant Deficiency relating to System Controls and York Electrical Equipment. This item has been reviewed by an NRC Specialist Inspector during the 85-04 inspection. The results of this review have been documented in NRC Inspection Report 85-04, dated April 23, 1985, which formally closes the item. The basis for closure is detailed in the inspection report, but can be summarized as follows. The corrective actions to remedy the deficiency have been formalized by DLC/SQC Inspection Plan 8.5.5, "Inspection of Vendor Internal Wiring," and by Appendix N to Engineering Spec. 2BVS-931, "Workmanship Program for Vendor, Internal, Class 1E Low Voltage, Instrumentation and Control Wiring, Inspection, Acceptance, and Repair/Rework Control." Pursuant to the requirements of 10CFR50.55(e), it is anticipated that this will be the final report on this matter.

DUQUESNE LIGHT COMPANY

SUBSCRIBED AND SWORN TO BEFORE ME THIS
12th DAY OF July, 1985.

Anita Elaine Reiter
Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986

JS/wjs

By

J. J. Carey
Vice President

cc: Mr. A. E. Finkel
Mr. B. K. Singh, Project Manager
Mr. J. M. Taylor, Director (3)
Mr. G. Walton, NRC Resident Inspector
INPO Records Center
NRC Document Control Desk

8508090560 850712
PDR ADOCK 05000412
S PDR

1/0
1E27

COMMONWEALTH OF PENNSYLVANIA)
) SS:
COUNTY OF ALLEGHENY)

On this 12th day of July, 1985, before me, a
Notary Public in and for said Commonwealth and County, personally appeared
J. J. Carey, who being duly sworn, deposed and said that (1) he is Vice
President of Duquesne Light, (2) he is duly authorized to execute and file
the foregoing Submittal on behalf of said Company, and (3) the statements set
forth in the Submittal are true and correct to the best of his knowledge.

Anita Elaine Reiter
Notary Public

ANITA ELAINE REITER, NOTARY PUBLIC
ROBINSON TOWNSHIP, ALLEGHENY COUNTY
MY COMMISSION EXPIRES OCTOBER 20, 1986