



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 21, 2020

LICENSEE: Indiana Michigan Power Company, LLC

FACILITY: Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF MAY 4, 2020, TELECONFERENCE WITH INDIANA MICHIGAN POWER COMPANY REGARDING DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2 (EPID L-2020-LRM-0037)

On May 4, 2020, a Category I public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Indiana Michigan Power Company (the licensee) via teleconference. The purpose of the meeting was to discuss planned license amendment requests for the Donald C. Cook Nuclear Plant (CNP), Unit Nos. 1 and 2, related to extending the Type A test (also known as integrated leak rate test (ILRT)) interval beyond the currently approved 15-year requirement. The meeting notice, dated April 24, 2020, and agenda are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML20115E458. A list of attendees is provided as the enclosure.

The licensee indicated that potential license amendments would be needed to extend the ILRT frequency by one refueling cycle; which would exceed the 15-year frequency required by the technical specifications. The licensee cited that the basis for the potential amendments would be the forecasted resurgence on the COVID-19 infections in the Fall time frame. With this forecast, CNP is attempting to limit the length of the outage in order to limit the opportunity for the spread of COVID-19 to essential plant workers. The licensee indicated that the amendments would consider the guidance in Regulatory Issue Summary 2008-27, "Staff Position on Extension of the Containment Type A Test Interval Beyond 15 Years Under Option B of Appendix J To 10 CFR Part 50."

No members of the public participated in the meeting. No regulatory decisions were made at this meeting.

Please direct any inquiries to me at 301-415-2855, or Scott.Wall@nrc.gov.

Sincerely,

/RA/

Scott P. Wall, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

Enclosure: List of Attendees

cc: Listserv

LIST OF ATTENDEES

MAY 4, 2020, PUBLIC MEETING WITH I&M

DONALD C. COOK NUCLEAR PLANT, UNIT NOS. 1 AND 2

PLANNED LICENSE AMENDMENT REQUEST RELATED TO

INTEGRATED LEAK RATE TEST INTERVALS

Name	Organization
Scott Wall	Nuclear Regulatory Commission (NRC)
Ahsan Sallman	NRC
Jerry Dozier	NRC
Bob Pettis	NRC
Brian Wittick	NRC
Steve Smith	NRC
Alex Schwab	NRC
Jerry Bettie	NRC
Michael Scarpello	Indiana Michigan Power Company (I&M)
Helen Levendosky	I&M
Dave Aubrey	I&M
Budd Haemer	I&M
Greg Hill	I&M
Chris Peckat	I&M
Gary Sanders	I&M
Brad Culwell	I&M
Jim Heyeck	Jensen Hughes
Eric Thornsby	Jensen Hughes
Matt Johnson	Jensen Hughes

SUBJECT: SUMMARY OF MAY 4, 2020, TELECONFERENCE WITH INDIANA MICHIGAN
POWER COMPANY REGARDING DONALD C. COOK NUCLEAR PLANT,
UNIT NOS. 1 AND 2 (EPID L-2020-LRM-0037) DATED MAY 21, 2020

DISTRIBUTION:

PUBLIC

PM File Copy

RidsNrrLASRohrer Resource

RidsRgn3mailCenter Resource

RidsAcrs_MailCTR Resource

RidsNrrPmDCCook Resource

RidsNrrDorlLpl3 Resource

RidsNrrDnrINphp Resource

RidsNrrDorl Resource

RidsOpaMail Resource

PMNS Resource

ADAMS Accession No. ML20133K128

***via e-mail**

OFFICE	NRR/DORL/LPL3/PM*	NRR/DORL/LPL3/LA*	NRR/DORL/LPL3/BC*	NRR/DORL/LPL3/PM*
NAME	SWall	SRohrer	NSalgado	SWall
DATE	05/14/2020	05/14/2020 /c/	05/21/2020	05/21/2020

OFFICIAL RECORD COPY