



Portland General Electric Company

Bart D. Withers Vice President

October 17, 1985

Trojan Nuclear Plant  
Docket 50-344  
License NPF-1

Director of Nuclear Regulation  
ATTN: Mr. Edward J. Butcher, Jr., Acting Chief  
Operating Reactor Branch No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington DC 20555

Dear Sir:

PGE Response to Request for Additional  
Information Relating to Generic Letter 83-28

In response to a recent telephone conversation with Lisa Lazo, NRC's  
Project Manager for the Trojan Nuclear Plant, additional information  
concerning Generic Letter 83-28 is provided in Attachment A.

Sincerely,

Bart D. Withers  
Vice President  
Nuclear

Attachment

Subscribed and sworn to before me this 17th day of October 1985.



Notary Public of Oregon

My Commission Expires:

August 9, 1987

8510220151 851017  
PDR ADOCK 05000344  
P PDR

A055  
1/1

Trojan Nuclear Plant  
Docket 50-344  
License NPF-1

Mr. Edward J. Butcher, Jr.  
October 17, 1985  
Attachment A

PGE RESPONSE TO REQUEST FOR ADDITIONAL  
INFORMATION ON GENERIC LETTER 83-28, POSITION 3.2.2

NRC Concern

PGE's previous responses to Position 3.2.2, "Review of Test Recommendations and Guidance", did not provide adequate assurance that vendor service bulletins and recommendations associated with all safety-related equipment not covered by Westinghouse had been properly considered for inclusion in Trojan procedures.

PGE Response

In PGE's response to Position 3.2.2, dated July 19, 1985, PGE committed to review all safety-related technical manuals for accuracy and consistency and update the manuals, as necessary, by July 1987. In order to satisfy NRC concerns, PGE further commits to revise Nuclear Division Procedure NDP 100-3, Updating Technical Manuals, to require a review of applicable safety-related procedures when a significant revision to a technical manual is required.