

TABLE 3.3-11
ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>MINIMUM NUMBER OF CHANNELS</u>
1. Reactor Coolant System Subcooling Margin Monitor	2	1
2. PORV Position Indicator*	1/valve	1/valve
3. PORV Block Valve Position Indicator**	1/valve	1/valve
4. Safety Valve Position Indicator (Acoustical Flow)	1/valve	1/valve
5. Auxiliary Feedwater Flow Rate	4 per pump	2 per pump
6. Pressurizer Water Level	3	2
7. Containment Atmospheric Pressure (-10 to 190 psig)	2	1
8. Containment Water Level (Wide Range)	2	1
9. Containment Water Level (Narrow Range)	1/sump	1/sump
10. Core Exit Thermocouples	4/core quadrant#	2/core quadrant#
11. Reactor Vessel Level Instrumentation System##	2	1

* Not applicable if the associated block valve is in the closed position.

** Not applicable if the block valve is verified in the closed position and power removed.

The core exit thermocouples required to be OPERABLE shall be those which are displayed on the Subcooling Margin Monitors.

Effective upon PGE's declaration of system operability and NRC approval to operate the system.

TABLE 4.3-7

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
1. Reactor Coolant System Subcooling Margin Monitor	M	R	
2. PORV Position Indicator	M		R
3. PORV Block Valve Position Indicator	M		R
4. Safety Valve Position Indicator (Acoustical Flow)	M		R
5. Auxiliary Feedwater Flow Rate	M*	R	
6. Pressurizer Water Level	M	R	
7. Containment Atmospheric Pressure (-10 to 190 psig)	M	R	
8. Containment Water Level (Wide Range)	M	R	
9. Containment Water Level (Narrow Range)	M	R	
10. Core Exit Thermocouples	M	R**	
11. Reactor Vessel Level Instru- mentation System#	M	R	

* Not applicable in Modes 1 and 2.

** Calibration shall consist of calibrating the thermocouple indicators.

Effective upon PGE's declaration of system operability and NRC approval to operate the system.

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION


In the Matter of)	
)	
PORTLAND GENERAL ELECTRIC COMPANY,)	Docket 50-344
THE CITY OF EUGENE, OREGON, AND)	Operating License NPF-1
PACIFIC POWER & LIGHT COMPANY)	
)	
(TROJAN NUCLEAR PLANT))	

CERTIFICATE OF SERVICE

I hereby certify that copies of License Change Application 125 to the Operating License for Trojan Nuclear Plant, dated August 7, 1985, have been served on the following by hand delivery or by deposit in the United States mail, first class, this 7th day of August 1985:

Mr. Lynn Frank, Director
State of Oregon
Department of Energy
Labor & Industries Bldg, Rm 102
Salem OR 97310

Mr. Robert L. King
Chairman of County Commissioners
Columbia County Courthouse
St. Helens OR 97051



G. A. Zimmerman, Manager
Nuclear Regulation Branch
Nuclear Safety & Regulation


Subscribed and sworn to before me this 7th day of August 1985.





Notary Public of Oregon

My Commission Expires:



August 9, 1987