

TABLE 3.1.1 (CONT'D)

- v. These functions not required to be operable when the ADS is not required to be operable.
- w. These functions must be operable only when irradiated fuel is in the fuel pool or reactor vessel and secondary containment integrity is required per specification 3.5.B.
- y. The number of operable channels may be reduced to 2 per Specification 3.9-E and F.
- z. The bypass function to permit scram reset in the shutdown or refuel mode with control rod block must be operable in this mode.
- aa. Pump circuit breakers will be tripped in 10 seconds \pm 15% during a LOCA by relays SK7A and SK8A.
- bb. Pump circuit breakers will trip instantaneously during a LOCA.
- cc. Only applicable during startup mode while operating in IRM range 10.
- dd. If an isolation condenser inlet (steam side) isolation valve becomes or is made inoperable in the open position during the run mode comply with Specification 3.8.E. If an AC motor-operated outlet (condensate return) isolation valve becomes or is made inoperable in the open position during the run mode comply with Specification 3.8.F.
- ee. With the number of operable channels one less than the Min. No. of Operable Instrument Channels per Operable Trip Systems, operation may proceed until performance of the next required Channel Functional Test provided the inoperable channel is placed in the tripped condition within 1 hour.
- ff. This function is not required to be operable when the associated safety bus is not required to be energized or fully operable as per applicable sections of these technical specifications.
- *gg. these functions are not required to be operable when secondary containment is not required to be maintained or when the conditions of Sections 3.5.b.1.a, b, c, and d are met, and reactor water level is closely monitored and logged hourly. The Standby Gas Treatment System will be manually initiated if reactor water level drops to the low level trip set point.
- * This note is applicable only during the Cycle 10M outage.