

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) D.C. COOK NUCLEAR PLANT, UNIT 1										DOCKET NUMBER (2) 0 5 0 0 0 3 1 5 1 OF 0 1										PAGE (3) 1 OF 0 1	
TITLE (4) FAILURE TO MEET TECHNICAL SPECIFICATION REQUIRED INSTRUMENT CALIBRATION FREQUENCY																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)								
0 9	1 6	8 5	8 5	0 4	7	0 0	1 0	1 6	8 5	D.C. COOK, UNIT 2				0 5 0 0 0 3 1 6							
OPERATING MODE (9) 5			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR § (Check one or more of the following) (11)																		
POWER LEVEL (10) 0 1 0 0		20.402(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)							
		20.405(a)(1)(i)				50.36(c)(1)				50.73(a)(2)(v)				73.71(c)							
		20.405(a)(1)(ii)				50.36(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)							
		20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)											
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)											
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)											
LICENSEE CONTACT FOR THIS LER (12)																					
NAME A.A. BLIND - ASSISTANT PLANT MANAGER										TELEPHONE NUMBER 6 1 1 6 4 6 5 1 - 5 9 1 0 1											
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDs												
SUPPLEMENTAL REPORT EXPECTED (14)										EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR							
YES (If yes, complete EXPECTED SUBMISSION DATE) X NO																					
ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)																					
<p>ON SEPTEMBER 16, 1985, WITH BOTH UNITS 1 AND 2 IN MODE 5 (COLD SHUTDOWN), IT WAS DETERMINED THAT THE FOLLOWING INSTRUMENTATION WAS NOT CALIBRATED AT A FREQUENCY OF ONCE EVERY 18 MONTHS AS REQUIRED BY TECHNICAL SPECIFICATIONS:</p> <p>CONTAINMENT PRESSURE ALARMS (PPA-310 AND PPA-312), TECHNICAL SPECIFICATION 3/4.3.3.8 (UNIT 1) AND 3/4.3.3.6 (UNIT 2).</p> <p>ICE CONDENSER FAN COOLER DRAIN POT RECORDER (DLR-610), TECHNICAL SPECIFICATION 3/4.4.6.1b (UNIT 1 AND UNIT 2).</p> <p>CONTAINMENT VENTILATION UNIT DRAIN POT LEVEL INDICATOR (VLI-350), TECHNICAL SPECIFICATION 3/4.4.6.1b (UNIT 1 AND UNIT 2).</p> <p>THE ABOVE LISTED INSTRUMENTS WERE NOT INCLUDED IN THE PLANT'S NUCLEAR TEST SCHEDULE. THE DETERMINATION THAT THESE INSTRUMENTS WERE RELATED TO THE PLANT'S TECHNICAL SPECIFICATIONS WAS MADE FOLLOWING A REVIEW OF CALIBRATION PROCEDURES AND TECHNICAL SPECIFICATION SURVEILLANCE REQUIREMENTS.</p> <p>CALIBRATION OF THE INSTRUMENTS WAS COMPLETED ON SEPTEMBER 16, 1985. ALL AS FOUND DATA WAS WITHIN SPECIFICATIONS.</p> <p>TO PREVENT RECURRENCE, THE CALIBRATION OF THE SUBJECT INSTRUMENTS HAS BEEN ADDED TO THE NUCLEAR TEST SCHEDULE.</p> <p>PREVIOUS OCCURRENCES OF A SIMILAR NATURE WERE REPORTED IN LERs: 50-315/85-043, 50-316/85-025, AND 50-316/85-021.</p>																					

JE22
1/1



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

October 16, 1985

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Operating License DPR-58
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10CFR50.73
entitled Licensee Event Reporting System, the following
report/s are being submitted:

RO 85-47-0

Sincerely,


for W.G. Smith, Jr.
Plant Manager

/cbm

Attachment

cc: John E. Dolan
J.G. Keppler, RO:III
M.P. Alexich
R.F. Kroeger
H.B. Brugger
R.W. Jurgensen
NRC Resident Inspector
R.C. Callen, MPSC
G. Charnoff, Esq.
D. Hahn
INPO
PNSRC
J.F. Stietzel
A.A. Blind
Dottie Sherman, ANI Library

IE22
1/1