

Appendix B

NOTICE OF DEVIATION

Ohio State University

Docket No. 50-150

As a result of the inspection conducted on August 26-28, 1985, it appears that certain of your activities deviate from commitments made to the NRC by the Ohio State University.

Deviation

The Hazards Summary Report for the Nuclear Reactor Laboratory, Chapter 2, revised on July 3, 1985, states in Section 2.2 that written procedures, reviewed and approved by a licensed Senior Reactor Operator, shall be in effect and followed.

Contrary to the above, on two occasions, Procedure IM-01, Use of the RY-4 Jumper, was not followed in documenting the use and approval of the installation and removal of the RY-4 Jumper and on one occasion the documentation of SRO notification of a high radiation smear per Procedure RS-08, NRL Smear Survey, was not followed.

8510280191 850918
PDR ADOCK 05000150
G PDR