

TABLE II

U S NUCLEAR REGULATORY COMMISSION  
 OFFICE OF INSPECTION AND ENFORCEMENT  
 CONFIRMATORY MEASUREMENTS PROGRAM  
 FACILITY: PR ISL  
 FOR THE 4 QUARTER OF 1984

SAMPLE	ISOTOPE	-----NRC-----		----LICENSEE----		---LICENSEE:NRC---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	BETA	1.1E-05	4.0E-07	1.4E-05	0.0E-01	1.2E 00	2.9E 01	A
	H-3	3.2E-05	7.0E-07	4.2E-05	0.0E-01	1.3E 00	4.6E 01	A
	SR-89	5.8E-08	8.0E-09	3.9E-08	0.0E-01	6.7E-01	7.3E 00	A
	SR-90	0.0E-01	3.0E-09	8.0E-09	0.0E-01	0.0E-01	0.0E-01	N

## T TEST RESULTS:

A=AGREEMENT

I=DISAGREEMENT

\*=CRITERIA RELAXED

N=NO COMPARISON