

WILLIAM G. COUNCIL  
EXECUTIVE VICE PRESIDENT

October 16, 1985

Mr. R. P. Denise, Director  
Division of Reactor Safety and Projects  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76012

OCT 21 1985

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NO. 50-445  
ELECTRICAL RACEWAY SUPPORT SYSTEM  
QA FILE: CP-85-31, SDAR-192

Dear Mr. Denise:

On August 27, 1985, we verbally notified your Mr. D. Hunnicutt of a deficiency regarding the possible impact of previously unconsidered weight on the electrical raceway support system imposed by the installation of separation barrier and radiant energy shield material. We have submitted an interim report logged TXX-4564, dated September 19, 1985.

We are continuing our evaluation and anticipate completion by January 22, 1986.

Very truly yours,

*W. G. Council*

W. G. Council

By: *J. S. Marshall*  
J. S. Marshall  
Licensing Supervisor

JCH/grr

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

8510280487 851016  
PDR ADOCK 05000445  
S PDR

85-954