

Docket Nos. 50-282  
and 50-306

October 18, 1985

Mr. D. M. Musolf  
Nuclear Support Services Department  
Northern States Power Company  
414 Nicollet Mall - 8th Floor  
Minneapolis, Minnesota 55401

Dear Mr. Musolf:

The Commission has completed the review of your November 4, 1983 response to Generic Letter 83-28 Items 3.1.3 and 3.2.3 Post-Maintenance Testing of Reactor Trip System Components and All Other Safety-Related Equipment, for the Prairie Island Nuclear Plant, Unit Nos. 1 and 2. Items 3.1.3 and 3.2.3 are concerned with the review of existing technical specifications for post-maintenance testing requirements that may degrade rather than enhance safety.

Based on the review of your response, we have concluded that at the present time no post-maintenance test requirements were identified in the technical specifications that degrade safety. However, as part of your continuing evaluation, you should factor in such reviews to future technical specification changes to assure that future post-maintenance testing does not degrade the level of safety.

On this basis, we find your responses to these items are adequate in content and therefore are acceptable. We consider our review of items 3.1.3 and 3.2.3 complete.

Sincerely,

Edward J. Butcher, Acting Chief  
Operating Reactors Branch No. 3  
Division of Licensing

cc: See next page

Distribution:

|              |              |
|--------------|--------------|
| Docket File  | DDiIanni     |
| NRC & L PDRs | ACRS 10      |
| OELD         | BGrimes      |
| PKreutzer    | Branch Files |
| HThompson    | EButcher     |
| EJordan      |              |
| JPartlow     |              |

ORB#3:DL  
PKreutzer  
11/1/85

ORB#3:DL  
DDiIanni;ef  
10/17/85

ORB#3:DL  
EButcher  
10/17/85

8510290437 851018  
PDR ADOCK 05000282  
P PDR

Mr. D. M. Musolf  
Northern States Power Company

Prairie Island Nuclear Generating  
Plant

cc:  
Gerald Charnoff, Esq.  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, NW  
Washington, DC 20036

Executive Director  
Minnesota Pollution Control Agency  
1935 W. County Road, B2  
Roseville, Minnesota 55113

Mr. E. L. Watzl, Plant Manager  
Prairie Island Nuclear Generating Plant  
Northern States Power Company  
Route 2  
Welch, Minnesota 55089

Jocelyn F. Olson, Esq.  
Special Assistant Attorney General  
Minnesota Pollution Control Agency  
1935 W. County Road, B2  
Roseville, Minnesota 55113

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Route #2, Box 500A  
Welch, Minnesota 55089

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Office of Executive Director for  
Operations  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. William Miller, Auditor  
Goodhue County Courthouse  
Red Wing, Minnesota 55066