

COMMONWEALTH EDISON COMPANYDOCKET NOS. 50-373 AND 50-374NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENTS TO FACILITY OPERATING LICENSES

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Commonwealth Edison Company (ComEd, the licensee) to withdraw its May 19, 1995, application proposing to amend Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, located in LaSalle County, Illinois.


The proposed amendment would have revised the technical specifications (TS) by extending the surveillance interval for visual inspection of certain fire protection valves from every 31 days to once per 18 months.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on July 5, 1995 (60 FR 35067). However, by letter dated July 15, 1996, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated May 19, 1995, and the licensee's letter dated July 15, 1996, which withdrew the application for license amendment. The above documents are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Jacobs Memorial Library, Illinois Valley Community College, Oglesby, Illinois 61348.

Dated at Rockville, Maryland, this 22 day of January 1997.

FOR THE NUCLEAR REGULATORY COMMISSION



Donna M. Skay, Project Manager
Project Directorate - III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation