

Official

AUG 07 1985

Florida Power and Light Company  
ATTN: Mr. J. W. Williams, Jr.  
Group Vice President  
Nuclear Energy Department  
P. O. Box 14000  
Juno Beach, FL 33408

Gentlemen:

SUBJECT: REPORT NOS. 50-250/84-23 AND 50-251/84-24

Thank you for your supplemental response of July 25, 1985, to our Notice of Violation issued on October 11, 1984, concerning activities conducted at your Turkey Point facility. We have evaluated your response to subsection 4.a and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

In our acknowledgement letter dated June 25, 1985, we requested that you address what review is being done or has been done to assure that similar design deficiencies have not occurred in the routing of power to miscellaneous relay rack equipment which may require safety-related power sources.

The supplemental response of July 25, 1985, does not address this concern; however, based on discussions between Mr. P. L. Pace of your staff and Mr. G. A. Pick of our staff, it is our understanding that you will submit a supplemental response by August 20, 1985, specifying what action is being taken or has been completed.

We appreciate your cooperation in this matter.

Sincerely,

Original Signed by  
Roger D. Walker

Roger D. Walker, Director  
Division of Reactor Projects

cc: ✓ C. M. Wethy, Vice President  
Turkey Point Nuclear Plant  
✓ C. J. Baker, Plant Manager  
Turkey Point Nuclear Plant  
✓ R. J. Acosta, Plant QA Superintendent

bcc: ✓ NRC Resident Inspector  
Document Control Desk  
State of Florida

RII  
GPick:jd  
8/6/85

RII  
SEIrod  
8/6/85

RII  
VBrownlee  
8/8/85

8508130530 850807  
PDR ADOCK 05000250  
PDR

1/0

IE01