

AUG 07 1985

Docket/License: 50-317/DPR-53
50-318/JPR-69

Baltimore Gas and Electric Company
ATTN: Mr. A. E. Lundvall, Jr.
Vice President, Supply
P. O. Box 1475
Baltimore, Maryland 21203

Gentlemen:

Subject: Combined Inspection Nos. 50-317/85-18, 50-318/85-16

This refers to the special safety inspection conducted by Mr. T. Elsasser of this office on July 15-19, 1985 at Calvert Cliffs Nuclear Power Plant, Units 1 and 2, Lusby, Maryland and to the discussions of our findings held with Mr. J. Tiernan and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection included: the operability status of the Post Accident Sampling System (PASS); the adequacy of alternate means of post accident sampling; PASS procurement, installation, and acceptance testing; installation and acceptance of other selected TMI Action Plan hardware modifications; and management and committee oversight of PASS. These areas are described in the Inspection Report which is enclosed with this letter.

We are concerned that aggressive action was not being implemented at the time of this inspection to correct the deficiencies identified during our previous inspection of PASS on June 24-28, 1985 (50-317/85-16, 50-318/85-14). The action plan submitted by Mr. Tiernan at the exit meeting appears to correct that situation and will be closely followed during future NRC inspections.

Potential enforcement action associated with PASS deficiencies will be discussed with you during an Enforcement Conference at the Region I Office on August 14, 1985. The details of this conference will be communicated to you in separate correspondence associated with Inspection Report 50-317/85-16, 50-318/85-14.

No reply to this letter is required. Your cooperation with us in this matter is appreciated.

Sincerely, ~~Original Signed By:~~

for *Ed C. McCabe*
Edward C. Wenzinger, Chief
Projects Branch No. 3
Division of Reactor Projects

Enclosure: NRC Region I Report 50-317/85-18, 50-318/85-16

8508130531 850807
PDR ADOCK 05000317
Q PDR

IEO1 1/1

AUG 07 1985

cc ./encls:

R. M. Douglass, Manager, Quality Assurance
L. B. Russell, Plant Superintendent
T. Magette, Administrator, Nuclear Evaluations
R. C. L. Olson, Principal Engineer, Nuclear Licensing & Analysis Unit
J. A. Tiernan, Manager, Nuclear Power Department
R. E. Denton, General Supervisor, Training and Technical Services
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

bcc w/encls:

Region I Docket Room (with concurrences)
Director, DRS
Director, DRSS
DRP Section Chief

RI: DFB

Foley/Trimble/fi
8/6/85

RI: DFB

Elsasser
8/7/85

RI: DPR

Wenzinger
8/7

OFFICIAL RECORD COPY