

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

June 25, 1985

BLRD-50-438/84-58

65 JUL 2 P 1:07

U.S. Nuclear Regulatory Commission  
Region II  
Attn: Dr. J. Nelson Grace, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Dear Dr. Grace:

BELLEFONTE NUCLEAR PLANT UNIT 1 - EXCESSIVE WIRING DEFICIENCIES IN BABCOCK  
AND WILCOX SUPPLIED CABINETS - BLRD-50-438/84-58 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector  
P. E. Fredrickson on November 14, 1984 in accordance with 10 CFR 50.55(e)  
as NCR 3675. Our interim reports were submitted on December 12, 1984 and  
March 29, 1985. Below is our third interim report. We expect to submit  
our next report on or about September 6, 1985. We consider 10 CFR Part 21  
applicable to this deficiency.

Interim Progress

Babcock and Wilcox (B&W) has issued field change packages (FCPs) 177 and 310  
to resolve the wiring and drawing deficiencies in the unit 1 ESFAS control  
cabinets as identified on the 68 separate NCRs. TVA is presently reviewing  
B&W's resolution of the programmatic problem.

If you have any questions, please get in touch with R. H. Shell at  
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. W. Hufham*  
J. W. Hufham, Manager  
Licensing and Risk Protection

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339