



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 * BEAUMONT, TEXAS 77704

AREA CODE 409 838-8631

October 24, 1985
File No. G9.5
RBG- 22456

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Butler:

River Bend Station - Unit 1
Docket No. 50-458

In response to your letter dated September 25, 1985, this weekly status report is being provided which identifies those license conditions and other commitments that have been completed during the previous week and cumulatively since issuance of the low power license. Attachment 1 is a cumulative listing of license conditions and Attachment 2 covers other important commitments that have been completed. Should you have any questions please contact W. J. Reed of my staff.

Sincerely,

J. E. Booker
Manager-Engineering
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB/WJR/LAE/ko

Attachments

cc: Mr. Robert Martin RIV
Mr. Dwight Chamberlain SRI

8510300132 851024
PDR ADOCK 05000458
R PDR

✓ 3001
11

ATTACHMENT 1

October 24, 1985

RBG- 22456

COMPLETED LICENSE CONDITIONS

<u>License Condition No.</u>	<u>Description</u>	<u>Comments</u>
L/C (1)2.a	Modify operating procedures to monitor control room HVAC cooling water (DR-314).	GSU letter 9/26/85
L/C (1)2.f	Complete HVAC charcoal loading and testing.	GSU letter 9/26/85
L/C (1)3.a.11	Fire-wrap control building electrical raceways.	GSU letter 9/26/85
L/C (1)2.b	Modify EOP relative to Limitorque operators (DR-280).	GSU letter 10/3/85
L/C (1)5.a	Fuel building sampling system.	GSU letter 10/3/85
L/C (1)7.a	Elgar fuse blocks (DR-287).	GSU letter 10/3/85
L/C (13)	Use advisors until operating staff experience requirements are met.	GSU letter 9/26/85
L/C 2.D	Exemption for operation up to five percent from GDC2-Seismic Qualification of two AOV's (1DFR*144 and 145).	GSU letter 10/3/85
L/C (1)1.a	Test off-gas system and off-gas vault refrigeration system.	GSU letter 10/10/85
L/C (1)3.a.1	Test CO2 fire protection for T/G.	GSU letter 10/10/85
L/C (1)3.c	Complete modifications/qualification of 1DFR AOV 144 and 145 (DR-193).	GSU letter 10/10/85
L/C (16) 3	Submit containment venting information.	GSU letter 10/10/85

ATTACHMENT I

October 24, 1985

RBG- 22456

Page 2

<u>License Condition No.</u>	<u>Description</u>	<u>Comments</u>
L/C (1)2.c	Verify Plant's air flow Characteristics.	GSU letter 10/17/85
L/C (1)2.d	Place sample panels in service after testing and calibration.	GSU letter 10/17/85
L/C (1)3.e	Modifications to reduce maximum emergency service load for Division I and II diesel generators.	

ATTACHMENT 2

October 24, 1985

RBG- 22456

OTHER COMMITMENTS COMPLETED

<u>Reference</u>	<u>Description</u>	<u>Comments</u>
RBG-21093 5/24/85	Perform internal sample review of Seismic Qualification Documentation before 5% power.	GSU letter 10/3/85
RBG-21378 6/24/85	Replace existing Rosemount 1153 B devices used for suppression pool water level measurement with Rosemount 1154 devices before exceeding 5% power.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	QA check of implementing and procedural documents pertaining to maintenance and surveillance of diesels against TDI Owner's Group and PNL recommendations.	GSU letter 10/3/85
SSER 3 8.3.1(2.4)	Incorporate PNL recommendations into TDI maintenance and surveillance programs.	GSU letter 10/3/85
TECH SPEC 6.8.4.d	Program to assure detection and prevention of Asiatic Clams.	GSU letter 10/10/85
RBG-21767 8/5/85	Submit Rev. 3 to Offsite Dose Calculation Manual.	GSU letter 10/10/85