



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W.
ATLANTA, GEORGIA 30323

OCT 23 1985

Attachment 1

Duke Power Company
ATTN: Mr. H. B. Tucker, Vice President
Nuclear Production Department
422 South Church Street
Charlotte, NC 28242

Gentlemen:

SUBJECT: CONFIRMATION OF ACTION - MCGUIRE NUCLEAR STATION
UNITS 1 AND 2 DOCKET NOS. 50-369 AND 50-370

This letter refers to the telephone conversation on October 22, 1985, between Mr. V. L. Brownlee of this office and Mr. N. A. Rutherford of Duke Power Company concerning control room and auxiliary building ventilation system filter testing.

With regard to the matters discussed, it is our understanding that you are taking the following actions:

1. Conduct air flow distribution tests for the auxiliary building ventilation filter systems and submit written test results to the Regional Office by October 28, 1985. These tests will be conducted in accordance with ANSI 510-1980 unless other criteria are established with the Office of Nuclear Reactor Regulation.
2. If acceptance criteria for the air flow distribution tests are not met, provide an analysis of the adequacy of the systems capability to meet the design function including the appropriateness of the surveillance program. This analysis will be provided to the NRC by October 29, 1985.
3. Review past test records to verify that all prerequisite tests pursuant to ANSI 510-1975 for the control room ventilation system have been conducted. Advise NRC by October 29, 1985, of the results of this review.

If your understanding of our discussion is different from that stated above, please inform this office immediately.

Sincerely,

John A. Nelson
J. Nelson Grace
Regional Administrator

CAL No. 50-369, 50-370/85-01

cc: T. L. McConnell, Station Manager

8510300214 851028
PDR ADDCK 05000369
PDR