

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1630 Chestnut Street Tower II

July 9, 1985

BLRD-50-438/81-56

BLRD-50-439/81-58

U.S. Nuclear Regulatory Commission

Region II

Attn: Dr. J. Nelson Grace, Regional Administrator

101 Marietta Street, NW, Suite 2900

Atlanta, Georgia 30323

Dear Dr. Grace:

BELLEFONTE NUCLEAR PLANT UNITS 1 AND 2 - REACTOR COOLANT SYSTEM SUPPORTS AND  
RESTRAINTS - BOLT TORQUES - BLRD-50-438/81-56, BLRD-50-439/81-58 -  
FINAL REPORT

We wish to correct a typographical error in our final report to you on the  
subject matter dated June 25, 1985. The figure for the minimum specified  
yield strength in the third line under the heading Safety Implication should  
read 150 ksi and not the misprinted 180 ksi. Please correct your records  
accordingly.

If you have any questions concerning this matter, please get in touch with  
R. H. Shell at FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*J. A. Hufham*

J. W. Hufham, Manager

Licensing and Risk Protection

cc: Mr. James Taylor, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. H. B. Barkley  
205 Plant Project Services  
P.O. Box 10935  
Lynchburg, Virginia 24505

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

8508140109 850709  
PDR ADOCK 05000438  
S PDR