

yellow

JUL 24 1985

Florida Power Corporation
ATTN: ~~Mr.~~ W. S. Wilgus
Vice President Nuclear Operations
P. O. Box 14042, M.A.C. H-2
St. Petersburg, FL 33733

Gentlemen:

SUBJECT: MEETING SUMMARY - CRYSTAL RIVER UNIT 3 - DOCKET NO. 50-302

This letter refers to the meeting conducted at your staff's request in the NRC Region II Office on July 16, 1985. This meeting was related to the application of Fire Protection, 10 CFR 50, Appendix R, and the forthcoming Appendix R inspection at Crystal River. Enclosed is a summary of the meeting topics.

It is our opinion that this meeting was beneficial, and provided for a better understanding of NRC's Appendix R Fire Protection inspection methodology and Florida Power Corporation's Appendix R analysis and design approach.

Should you have any questions concerning this matter, we will be pleased to discuss them.

Sincerely,

Virgil L. Brownlee for

Roger D. Walker, Director
Division of Reactor Projects

Enclosure:
Meeting Summary w/attachment

cc w/encl:

~~E.~~ M. Howard, Director
Site Nuclear Operations
~~P.~~ F. McKee, Nuclear Plant Manager
~~G.~~ R. Westafer, Manager
Nuclear Operations Licensing
and Fuel Management

bcc w/encl:

~~NRC~~ Resident Inspector
Document Control Desk
State of Florida
H. Silver, NRR
T. E. Conlon, RII
V. Panciera, RII
W. Miller, RII
G. Wiseman, RII
RII

WM:ls
07/17/85

RII *TE*
TEConlon
07/17/85

RII *AR*
ARHerdt
07/18/85

RII *AG*
AGibson
07/19/85

RII *B*
Brownlee
07/22/85

8508140157 850724
PDR ADDCK 05000302
G PDR

7/21/85

11 IE 45

ENCLOSURE

MEETING SUMMARY

Licensee: Florida Power Corporation

Facility: Crystal River Unit 3

Docket No.: 50-302

Facility License No.: DPR-72

A meeting was held in the NRC Region II office on July 16, 1985, to discuss the implementation of 10 CFR 50, Appendix R, Fire Protection, in preparation for the special inspection at Crystal River scheduled for July 29, through August 2, 1985.

The following items were discussed in detail: inspection schedule and scope, electrical associated circuit analysis, electrical modifications; fire protection features; plant shutdown procedures; emergency lighting; and oil collection system for the reactor coolant pump.

Attachment:
Attendance list

ATTACHMENT

ATTENDANCE LIST

Attendance at the FPC - NRC meeting on July 16, 1985, at the NRC Region II office.

Florida Power Corporation

S. Powell, Senior Nuclear Licensing Engineer
R. P. Schmiedel, Nuclear Electrical Engineer
M. Kirk, Nuclear Operations Technical Advisor
J. L. Russell, Senior Fire Protection Specialist

NRC Region II

V. Panciera, Chief, Projects Section 2B
A. B. Ruff, Electrical Engineer, Plant Systems Section
M. D. Hunt, Electrical Engineer, Plant Systems Section
G. R. Wiseman, Fire Protection Engineer, Plant Systems Section
W. H. Miller, Jr., Fire Protection Engineer, Plant Systems Section
T. F. McElhinney, Reactor Engineer, Plant Systems Section