

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

July 15, 1985


Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

RE: Catawba Nuclear Station, Unit 2  
Docket No. 50-414  
Significant Deficiency No. 414/85-06

Dear Dr. Grace:

Please find attached an update on the status of all outstanding corrective actions for this deficiency as outlined in the initial report transmitted to you on May 22, 1985.

Very truly yours,



Hal B. Tucker

LTP/mjf

Attachment

cc: Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC Resident Inspector  
Catawba Nuclear Station

Palmetto Alliance  
2135½ Devine Street  
Columbia, South Carolina 29205

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

Mr. Robert Guild, Esq.  
Attorney-at-Law  
P. O. Box 12097  
Charleston, South Carolina 29412

Mr. Jesse L. Riley  
Carolina Environmental Study  
Group  
854 Henley Place  
Charlotte, North Carolina 28207

85 JUL 16 P 8:33

8508140169 850715  
PDR ADOCK 05000414  
S PDR

11 IE27

Status Report on Corrective Action:

SD 414/85-06

All affected piping and equipment in the Chemical and Volume Control (NV) System has been evaluated and work initiated to replace or repair damaged components. All actions associated with the Non-conforming Item Reports and the Shutdown Requests have been completed with the following exceptions:

- Minor installation repairs to the newly installed Volume Control Tank.
- Repairs to remaining NV System pipe supports.
- Final calibration of NV System instrumentation.
- Repairs to several pipe supports in the Liquid Waste System Drain Line and a final inspection of piping and supports in this area.

All remaining work will be complete by August 15, 1985 by which time a final follow-up report will be submitted.