

DUKE POWER COMPANY

P.O. BOX 33189

CHARLOTTE, N.C. 28242

HAL B. TUCKER

VICE PRESIDENT  
NUCLEAR PRODUCTION

July 15, 1985

TELEPHONE  
(704) 373-4531

85 JUL 18 PM 8:33


Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 290-  
Atlanta, Georgia 30323

Re: Catawba Nuclear Station, Unit 2  
Docket No. 50-414  
Significant Deficiency No. 414/85-08

Dear Dr. Grace:

Please find attached an update on the status of all outstanding corrective actions for the subject deficiency as outlined in the initial report transmitted to you on May 31, 1985.

Very truly yours,



Hal B. Tucker

LTP/mjf

Attachment

cc: Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

Mr. Jesse L. Riley  
Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

Robert Guild, Esq.  
P. O. Box 12097  
Charleston, South Carolina 29412

Palmetto Alliance  
2135½ Devine Street  
Columbia, South Carolina 29205

NRC Resident Inspector  
Catawba Nuclear Station

8508140179 850715  
PDR ADOCK 05000414  
S PDR

1/1 IE27

Status Report on Corrective Action:

SD 414/85-08

A design evaluation of areas of possible overpressurization on the Residual Heat Removal System, the Boron Recycle System and the Nuclear Sampling System has been completed.

All piping was found to be acceptable, with the exception of 150 lb. flanges in the Boron Recycle System. These flanges have since been replaced.

The two Unit 2 heat exchangers were inspected and found acceptable for continued use. Nine valves required repair and have been reinstalled. One valve has been replaced. All affected valves have had the set pressures recalibrated.

All corrective action on this deficiency has been completed.