

Georgia Power Company
Route 2, Box 299A
Waynesboro, Georgia 30830
Telephone 404 554-9961 Ext. 3360
404 724-8114 Ext. 3360

D. O. Foster
Vice President and Project
General Manager
Vogtle Project



July 10, 1985

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 2900
101 Marietta Street, Northwest
Atlanta, Georgia 30323

File: X7BG03-M79
Log: GN-650

Reference: Vogtle Electric Generating Plant-Units 1 and 2; 50-424, 50-425;
Electrical Conductor Seal Assemblies

Attention: Mr. J. Nelson Grace

On June 13, 1985, Mr. R. E. Folker, Vogtle Project Quality Assurance Engineer, informed Mr. W. H. Rankin of the USNRC of a potentially reportable condition involving the Class 1E Electrical Conductor Seal Assemblies. Bechtel Power Corporation is performing an engineering evaluation to determine if a reportable condition could exist. At this time, Georgia Power Company expects to inform the NRC of the results of this evaluation by September 28, 1985.

This response contains no proprietary information and may be placed in the NRC Public Document Room.

Yours truly
D. O. Foster

D. O. Foster

REF/DOF/tdm

xc: U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

R. J. Kelly
R. E. Conway
G. F. Head
J. T. Beckham
R. A. Thomas
D. E. Dutton
W. F. Sanders (NRC)
R. H. Pinson
B. M. Guthrie
E. D. Groover
R. W. McManus

J. A. Bailey
O. Batum
H. H. Gregory
W. T. Nickerson
D. R. Altman
D. L. Kinnsch (BPC)
J. L. Vota (W)
L. T. Gucwa
C. E. Belflower
F. B. Marsh (BPC)
G. A. McCarley

G. Bockhold
P. D. Rice
C. S. McCall (OPC)
E. L. Blake, Jr.
(Shaw, et. al.)
J. E. Joiner
(Troutman, et. al.)
D. C. Teper (GANE)
L. Fowler (LEAF)
T. Johnson (ECPG)

8508140206 850710
PDR ADDCK 05000424
S PDR

11 IE19
IE22