

AUG 12 1985

Mr. Jack M. Fulton, Chairman  
General Electric Owners Group  
Boston Edison Company  
25 Braintree Hill Office Park  
Braintree, MA 02184

Dear Mr. Fulton:

SUBJECT: IE DRAFT BULLETIN: MOTOR-OPERATED VALVE FAILURES DURING PLANT  
TRANSIENTS DUE TO IMPROPER SWITCH SETTINGS

The enclosed draft bulletin is being considered for issuance to all nuclear power reactor facilities holding an operating license or construction permit.

We would appreciate your comments on the draft bulletin and any input on the anticipated burden the bulletin may impose on nuclear utilities. Any comments received prior to August 23, 1985 will be considered in the preparation of the final draft to be presented to the Committee to Review Generic Requirements.

If you have any questions regarding this matter, please feel free to contact me or Mr. Henry Bailey of my staff. I can be reached at (301) 492-4193 and Henry at (301) 492-9006.

Sincerely,

Original signed by *E.L. for*

Charles E. Rossi, Chief  
Events Analysis Branch  
Division of Emergency Preparedness  
and Engineering Response  
Office of Inspection and Enforcement

Enclosure: IE draft bulletin

Distribution:

PDR

*DCS*

DEPER R/F

EAB R/F

CRossi

RBaer

ELJordan

HBailey

RKiessel

8508140468 850812  
PDR I&E  
MISC

PDR

*HB*  
EAB DEPER: IE  
HBailey:mj  
8/9/85

*CR*  
EAB DEPER: IE  
CRossi  
8/12/85