

October 21, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-85-97

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Florida Power & Light Company  
Turkey Point Unit 3  
Docket No. 50-250  
Homestead, Florida

Licensee Emergency Classification:  
☐ Notification of Unusual Event  
☐ Alert  
☐ Site Area Emergency  
☐ General Emergency  
☒ Not Applicable

SUBJECT: SHUTDOWN IN EXCESS OF 48 HOURS

The licensee has notified Region II that the reactor will be shut down for about eight to ten days to repair a boot seal between the condenser and the low pressure turbine.

Additional work on power operated relief valves is planned.

Region II will conduct routine followup.

The State of Florida has been informed.

Region II received initial notification of this event by telephone from the resident inspector at 10:00 a.m. (EDT) on October 21.

This information is current as of 10:00 a.m. on October 21.

Contact: S. Guenther, 242-3187

S. Elrod, 242-5536

DISTRIBUTION:

H. Street 2:11  
Chairman Palladino  
Comm. Roberts  
Comm. Asselstine  
Comm. Bernthal  
Comm. Zech  
SECY  
ACRS  
CA  
PDR

MNBB 2:10  
EDO  
PA  
MPA  
ELD  
Air Rights 2:15  
SP

Phillips 2:40  
NRR

E/W 2:24  
IE  
OIA  
AEOD

INPO 2:16  
NSAC

Willste 2:14  
NMSS  
RES

MAIL:  
ADM:DMB  
DOT: Trans Only  
Applicable State

Regions: RA 2:20, RII 2:19, RIV 2:23, RV 2:22  
Licensee: \_\_\_\_\_  
(Reactor Licensees)  
Applicable Resident Site 2:30

8511040252 851021  
PDR I&E  
PNO-II-85-097 PDR

01 DMB  
IE-34