

OCT 30 1985

Docket No. 50-244

Rochester Gas and Electric Corporation
ATTN: Mr. Roger W. Kober
Vice President
Electric and Steam Production
49 East Avenue
Rochester, New York 14649

Gentlemen:

Subject: Inspection No. 50-244/85-20

This refers to the routine safety inspection conducted by Mr. W. Lazarus of this office and other members of an NRC team on September 25-27, 1985, at the R. E. Ginna Nuclear Power Plant of activities authorized by NRC License No. DPR-18 and to the discussions of our findings held by Mr. Lazarus with you and other members of your staff at the conclusion of the inspection.

The areas examined during this inspection were limited to observation of the Emergency Exercise conducted on September 26, 1985. Within the scope of this inspection, no violations were observed.

We are concerned however, that the Emergency Operations Facility (EOF) dose assessment team did not effectively utilize information available to perform accurate, timely dose assessment calculations which could have been used to determine or verify protective action recommendations. We request that you provide a written response within 30 days of receipt of this letter detailing your proposed actions to upgrade performance in this area.

Your cooperation with us in this matter is appreciated.

Sincerely,
Original Signed By:

Ronald R. Bellomy / *tm*

Thomas T. Martin, Director
Division of Radiation Safety
and Safeguards

Enclosure: NRC Region I Inspection Report No. 50-244/85-20

8511040323 851030
PDR ADOCK 05000244
Q PDR

OFFICIAL RECORD COPY

IE35
11

cc w/encl:

Harry H. Voigt, Esquire
Central Records (4 copies)
Director, Power Division
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
DPRP Section Chief
FEMA Region II

RI:DRSS
Lazarus/geb
10/18/85

RI:DRSS
Harpster
10/22/85

RI:DRSS
Bellamy
10/28/85

~~RI:DRSS
Martin~~

OFFICIAL RECORD COPY

IR GINNA 85-20 - 0001.1.0
10/16/85