

Specification

Radiological control procedures shall be written and made available to all station personnel, and shall state permissible radiation exposure levels. The radiation protection program shall meet the requirements of 10 CFR 20.

Paragraph 20.203 - Caution signs, labels and signalsParagraph 20.1601 - Control of Access to High Radiation Areas

In lieu of the "control device" required by paragraph 20.1601(a)(1) or "alarm signal" required by paragraph 20.203(e)(2), 20.1601(a)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mRem/hr*, but less than 1000 mRem/hr*, accessible to personnel and in which a major portion of the whole body could receive in one hour a dose greater than 100 mRem shall be barricaded and conspicuously posted as a high radiation area, and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP)**. Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by at least one of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of these conditions.
- c. Coverage by an individual qualified in radiation protection procedures who is equipped with a radiation dose rate monitoring device. This individual shall be responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance as specified by the plant health physics supervisor on the RWP.

The requirements above shall also apply to areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mRem. In addition, these areas shall be provided with locked doors to prevent unauthorized entry, and the keys shall be maintained under the administrative control of the Duty Shift Supervisor (DSS) and/or plant health physics supervision. Doors shall remain locked except

* Measurement made Dose rate at no more than 48"-30 centimeters from the source of radioactivity radiation.

** Health physics qualified personnel or personnel escorted by health physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection and operational surveillance duties, provided they comply with approved radiation protection procedures regarding entry into high radiation areas and radiological conditions remain stable.