

October 22, 1985

Mr. R. L. Andrews
Division Manager - Nuclear Production
Omaha Public Power District
1623 Harney Street
Omaha, Nebraska 68102

Dear Mr. Andrews:

The Commission has completed the review of your November 4, 1983 response to Generic Letter 83-28 Items 3.1.3 and 3.2.3 Post-Maintenance Testing of Reactor Trip System Components and All Other Safety-Related Equipment, for the Fort Calhoun Station, Unit No. 1. Items 3.1.3 and 3.2.3 are concerned with the review of existing technical specifications for post-maintenance testing requirements that may degrade rather than enhance safety.

Based on the review of your response, we have concluded that at the present time no post-maintenance test requirements were identified in the technical specifications that degrade safety. However, as part of your continuing evaluation, you should factor in such reviews to future technical specification changes to assure that future post-maintenance testing does not degrade the level of safety.

On this basis, we find your responses to these items are adequate in content and therefore are acceptable. We consider our review of items 3.1.3 and 3.2.3 complete.

Sincerely,

Edward J. Butcher, Acting Chief
Operating Reactors Branch No. 3
Division of Licensing

cc: See next page

Distribution:

~~Docket File~~

NRC & L PDRs

QELD

PKreutzer

HThompson

EJordan

JPartlow

LKintner

ETourigny

ACRS 10

BGrimes

Branch Files

EButcher

DLasher

JHopkins

ORB#3:DL

PKreutzer

10/22/85

ORB#3:DL

ETourigny;ef

10/22/85

ORB#3:DL

EButcher

10/24/85

Mr. R. L. Andrews
Omaha Public Power District

Fort Calhoun Station
Unit No. 1

cc:

Harry H. Voigt, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, NW
Washington, D.C. 20036

Mr. Jack Jensen, Chairman
Washington County Board
of Supervisors
Blair, Nebraska 68023

Metropolitan Planning Agency
ATTN: Dagnia Prieditis
7000 West Center Road
Omaha, Nebraska 68107

Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 309
Fort Calhoun, Nebraska 68023

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Bethesda, Maryland 20814

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director
for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011