



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 13, 1985

Docket No. 50-312

Mr. R. J. Rodriguez
Assistant General Manager, Nuclear
Sacramento Municipal Utility District
6201 S Street
Post Office Box 15830
Sacramento, California 95813

Gentlemen:

SUBJECT: INSPECTION NO. 50-312/85-14

Enclosed is the report of the special team inspection conducted by R. C. Wilson and other NRC representatives on May 20-24, 1985, at the Rancho Seco site of Sacramento Municipal Utility District of activities authorized by NRC License No. DPR-54. The team's findings were discussed with you and members of your staff at the conclusion of the inspection. The inspection reviewed your implementation of a program as required by 10 CFR 50.49 for establishing and maintaining the qualification of electric equipment within the scope of 10 CFR 50.49. The inspection also included evaluations of the implementation of equipment qualification corrective action commitments made as a result of the January 17, 1983 Safety Evaluation Report (SER) and the December 10, 1982 Franklin Research Center Technical Evaluation Report (TER). Within this area, the inspection consisted of examinations of selected procedures and records, interviews with personnel, and observations by the inspectors.

The inspection determined that you have implemented a program to meet the requirements of 10 CFR 50.49 and your corrective action commitments relative to SER/TER deficiencies. The inspection identified three Open Items involving documentation of Rockbestos cable qualification, procedures implementation, and Limitorque operator T-drain removal. Your actions concerning these items will be addressed in a future NRC inspection. Full compliance with the requirements of 10 CFR 50.49 is required for restart from the spring 1985 refueling outage, and noncompliance after that time will result in enforcement action. Details of the concerns are discussed in the enclosed inspection report.

8508150412 850813
PDR ADOCK 05000312
G PDR

FOR CS PROCESSING

Original document not available to NRC

Certified by Sherry Meador

LE01

Sacramento Municipal
Utility District


- 2 -

August 13, 1985

Your corrective actions regarding the identified Open Items should not be delayed pending a future NRC inspection or further action by the NRC Region V office.

We are available to discuss any questions you have concerning this inspection.

Sincerely,

A handwritten signature in dark ink, appearing to read "Gary G. Zech". The signature is fluid and cursive, with the first name "Gary" and last name "Zech" clearly distinguishable.

Gary G. Zech, Chief
Vendor Program Branch
Division of Quality Assurance, Vendor
and Technical Training Center Programs
Office of Inspection and Enforcement

Enclosure:
Inspection Report No. 50-312/85-14

Sacramento Municipal Utility District

August 13, 1985

DISTRIBUTION:

✓ DCS
PDR
VPB Reading
DQAVT Reading
JTaylor
RVollmer
BGrimes
UPotapovs
GHubbard
RWilson
GHolahan, ORAB/NRR
RLaGrange, EQB/NRR
PShemanski, EQB/NRR
RKarsch, ORAB/NRR
SMiner, DL/NRR
RBorgen, Idaho National Engineering Laboratory
PBennett, Sandia National Laboratories
JBurdoin, RV
GPerez, Rancho Seco Resident, U.S.N.R.C.
14410 Twin Cities Road
Herald, CA 95638
TYoung, JR., RV
JThomas, DPC

VPB:DQAVT
RWilson:sam
7/29/85
REC'D 8/1/85

BC/VPB:DQAVT
EGZech
8/9/85

SC/VPB:DQAVT
UPotapovs
7/24/85

DIR:DQAVT
BGrimes
8/9/85

memo conc.
BC/ORAB:NRR
GHolahan
7/31/85

DIR:OLE
JTaylor
7/31/85

telephone conc.
ABC/EQB:NRR
RLaGrange
7/31/85

memo conc.
RV
TYoung, Jr.
7/31/85